



ARTICLE

Simulation-Based Analysis of Building Energy Consumption under Different Thermal Utilization Techniques

Xiang Ding^{1,2,3}, Huai Chen^{1,3}, Wenfeng Gao^{1,2,3,*}, Baihong Liu^{1,3} and Qiong Li^{1,3}

¹Solar Energy Research Institute, Yunnan Normal University, Kunming, China

²National Quality Inspection and Testing Center for Solar Water Heating Systems, Kunming, China

³Key Laboratory of Rural Energy Engineering of Yunnan, Kunming, China

*Corresponding Author: Wenfeng Gao. Email: sheva7@163.com

Received: 13 November 2025; Accepted: 22 January 2026; Published: 18 October 2026

ABSTRACT: Building sectors in China contributes more than 40% of the total national energy consumption, and thus efficient control of energy is important in meeting the 2-carbon target. This paper proposes QEMES-ASHP (Quantum-Enhanced Multi-Physics Energy Simulation with Air Source Heat Pump integration) as a real-time platform, combining thermal, electrical, and fluid dynamics modelling with adaptive control using AI. The main innovations of the framework include: (i) real-time multi-physics coupling, in which modelling heat-power-airflow interactions under dynamic climate conditions, (ii) machine learned system switching in solar-ASHP-PCM systems, and (iii) fractal-based time modelling, which uses a Brownian motion at fractional scales to account for energy demand fluctuations between microsecond and season scales and quantify uncertainty in a Bayesian uncertainty quantification for robust predictions. The quantum enhancement is the utilization of a variational quantum linear solver (VQLS), accelerating large-scale coupled matrices, with up to 20% faster convergence than classical solvers, and is compatible with classical HPC resources. Integration-first simulation paradigm is a name that characterizes the steady integration of various physics, predictive AI control, and uncertainty quantification into an integrated, real-time operation structure. Validation was carried out at a 200 m² IoT-instrumented test structure in 5 Chinese climate zones (hot-humid, hot-dry, temperate, cold, severe cold) and a 150+ sensor count constantly recording data over twelve months. Based on QEMES-ASHP as the reference, the findings indicate 31%–35% yearly energy savings, 15%–30% peak load saving, and PMV-based thermal comfort with the range of ± 0.15 , which is better than an advanced façade, radiant cooling, and thermal system with TES ($p < 0.001$). Computational speed was 20 percent faster, with the economic analysis paying back in 4.2 years. Life-cycle analysis suggests a 30%–40% decrease in the number of CO₂ emissions, which will be directly part of the carbon neutrality in China in 2060. QEMES-ASHP illustrates a simulation methodology that is both holistic and replicable, providing practical recommendations to architects, HVAC engineers, and policymakers who design next-generation net-zero smart buildings in a variety of Chinese climates.

KEYWORDS: QEMES-ASHP (Quantum-enhanced multi-physics energy simulation with air source heat pump integration); building energy optimization; multi-physics coupling; AI-driven thermal control; hybrid solar-ASHP-PCM systems; IoT-enabled smart buildings; fractal temporal modelling; Bayesian uncertainty quantification

1 Introduction

The construction industry is one of the energy-intensive fields in the world, consuming about 40 percent of the total energy use along with a significant percentage of the greenhouse gas emissions globally [1]. This issue is especially acute in China, where the construction industry takes more than 40 percent of

the national energy resources, and, accordingly, an efficient energy management system is the key to meeting the ambitious goals of the nation in the field of carbon peaking by 2030 and carbon neutrality by 2060 [2,3]. This rapid urbanization trend, where more than 60 percent of China's population is now living in urban environments, has contributed to the pressure in seeking energy-saving building technologies that can perform in different climatic zones, such as moist hot tropical climates to extreme cold continental climates [4,5].

Conventional building energy simulation methods are characterized by underlying constraints in the capability to handle building complexity in contemporary smart buildings. Traditional models are generally single-physics models that do not sufficiently describe complex relationships between thermal, electrical, and fluid dynamics of building systems that coexist at the same time [6,7]. The techniques tend to use constant values of operation and cannot follow the changes of the environment, leading to a huge discrepancy between the forecasted and actual performance of energy [8]. Moreover, the current simulation models are not real-time; hence, their applicability in the adaptive control system, where a response to the changing conditions must be fast, is constrained [9,10].

Additional complexity brought by the incorporation of renewable power systems, such as solar photovoltaic, air source heat pumps (ASHP), and phase change materials (PCM), lies outside the reach of conventional simulation techniques [11–13]. The existing methods normally treat the systems separately, without considering the synergistic actions and optimal switching schemes, which might considerably improve the overall system operations [14,15]. This is especially a problem with hybrid systems, where the optimum design can change depending on the real-time weather, occupancy, and fluctuations in energy demand [16,17].

Recent developments in artificial intelligence and machine learning can prove effective in proposing energy optimization [18,19]. Nevertheless, the majority of current methods of AI implementation pay attention to individual building performance components, e.g., HVAC control or energy prediction, and do not address the multi-physics processes that essentially control the behavior of buildings' energy [20,21]. Moreover, such techniques do not have sound uncertainty quantification tools, and they cannot be used in critical infrastructure projects where reliability is of utmost importance [22,23].

With the advent of quantum computing technologies, new opportunities based on solving computationally intensive optimization problems in the development of energy systems are unprecedented [24]. Variational quantum algorithms have demonstrated specific advantages in solving large-scale linear problems, in which multi-physics simulations rely [25,26]. Nevertheless, quantum-enhanced building energy simulation is a research void with a high potential impact, having been discovered only to a small degree [27,28].

The existing building energy management systems are also characterized by time modelling problems; they generally rely on time constants that cannot represent the fractal characteristics of the energy demand patterns [29]. Building energy use has self-similar behavior at many scales, ranging down to electrical oscillations of a few microseconds, and up to seasonal building thermal cycles, and demands a complex of mathematical models that can model this multi-scale nature [30]. Diffusion phenomena cannot be predicted by traditional methods with homogeneous time discretization, resulting in inefficient control choices and suboptimal system performance.

The literature gaps identified in the research also demonstrate some of the key challenges, which include: (1) the lack of complete multi-physics coupling models that can operate in real time, (2) the lack of integration of quantum-enhanced computational approaches to construct energy applications, (3) the lack of temporal modelling approaches that can characterize the multi-scale energy demand fluctuations, (4) the lack of

uncertainty quantification in AI-based building control systems, and (5) the lack of validation across climate zones to provide a broad range of applicability.

This research is aimed at eliminating these constraints by proposing a new real-time framework, QEMES-ASHP (Quantum-Enhanced Multi-Physics Energy Simulation with Air Source Heat Pump integration), which has been developed to combine the fundamental modelling of thermal, electrical, and fluid dynamics with AI-assisted adaptive control. This study was inspired by the necessity to enhance highly developed simulation technologies that could facilitate the carbon neutrality goals in China and offer viable solutions to the next generation of smart buildings. The three major innovations proposed include real-time multi-physics coupling, which models heat-power-airflow interactions in dynamic scenarios; machine learning-based hybrid system switching, which models the optimum interaction of solar-ASHP-PCM; and fractal-based temporal modelling, which models the fluctuation in energy demand across various time scales using a process called fractional Brownian motion.

In the quantum enhancement quantum solver, the solution of large-scale coupled matrices in multi-physics simulations is accelerated using a variational quantum linear solver (VQLS), which is compatible with large-scale classical high-performance computing resources. This is a solution to the computational bottleneck, which has been a limitation in the ability of real-time multi-physics simulation to be used in building applications.

The study aims and objectives will be to: (1) develop and validate a developed model of comprehensive quantum-enhanced multi-physics simulation model of building energy systems, (2) test the performance of the fractal based temporal models coupled with Bayesian quantification of uncertainty in order to generate robust predictive capability, (3) test the performance of AI based methods of adaptive control of hybrid renewable energy systems, (4) test the performance of the research on large scale experimental validation in various regions across China in order to ensure a large scale of applicability to the hybrid climatic areas, and (5) provide actionable guidelines for practical implementation in next-generation smart buildings.

This study has had several important implications for building energy simulation and sustainable building technologies:

1. **Novel Quantum-Enhanced Multi-Physics Framework:** Development of QEMES-ASHP, the first real-time quantum-enhanced simulation platform that simultaneously couples thermal, electrical, and fluid dynamics with AI-driven adaptive control. The integration of variational quantum linear solver (VQLS) achieves 20% faster convergence compared to classical solvers while maintaining compatibility with existing HPC infrastructure.
2. **Advanced Fractal-Based Temporal Modelling:** Fractional Brownian motion-based temporal modelling proposes and introduces an extension of one-dimensional temporal modelling that is able to describe the energy demand variations at a wide range of time scales, down to microsecond-scale cycles, up to seasonal cycles. This is used in conjunction with Bayesian quantification of uncertainty that offers unparalleled accuracy in forecasting building energy behavior in dynamic settings.
3. **AI-Driven Hybrid System Optimization:** Training of adaptive switching algorithms based on machine learning to optimally integrate solar-ASHP-PCM systems. The system is dynamically configured based on real-time environmental conditions, occupancy patterns, and energy demand forecasts in response to the framework.
4. **Comprehensive Multi-Climate Validation:** Multiple-stage extensive experimental validation of five different Chinese climate regions (hot-humid, hot-dry, temperate, cold, severe cold) in a 200 m² IoT-instrumented test building with 150+ sensors over 12 months, which shows wide applicability and strength.

5. **Integration-First Simulation Paradigm:** Development of a new simulation framework that fully combines multiple physics domains, predictive artificial intelligence control, and quantification of uncertainty within one framework of operation, without the current disjointed way to construct energy modelling.
6. **Practical Implementation Framework:** Many architects, HVAC engineers, and policymakers are currently given practical implementation guidelines and design principles to achieve a new generation of net-zero smart buildings, which combine the capabilities of advanced simulators with practical implementation.
7. **Carbon Neutrality Impact Assessment:** Measurable reduction of life-cycle CO₂ emissions (30–40 percent) that would offer a direct mechanism by which the 2060 carbon neutrality goals of China could be attained, by optimizing building energy consumption, which can be replicated nationwide.

The importance of this study is that it can change the way building energy simulation is performed (a) by the use of single-physics models, which do not operate in real-time, and (b) by fully integrated multi-physics models, which can operate in real-time. With the demonstration of a new paradigm of energy-efficient building design and operation between the advanced methods of quantum computing and the practical applications of building construction, the present work contributes to the future objectives of sustainable urbanization and the goals of climate action as expressed in [Table 1](#):

The rest of this paper is structured in the following way. [Section 2](#) includes a literature review with an overview of the previous research on multi-physics building simulations, AI-based energy management, and quantum-enhanced computational methods. [Section 3](#) explains the proposed methodology of QEMES–ASHP, such as the multi-physics modelling system, AI control, quantum-enhanced solver, and fractal-based time prediction. [Section 4](#) presents the experimental arrangement and testbed design, details the smart building specifications, multi-climate zone testing, comparison of the base systems, and the data gathering protocols. [Section 5](#) discusses the implementation, including the software architecture, hardware requirements, algorithm optimization, and system validation. [Section 6](#) gives the results and analysis with energy performance, thermal comfort analysis, economic analysis, environmental impact analysis, and comparative performance to other base systems. [Section 7](#) is the discussion of the findings, which includes technical innovations, implications of the findings, policy considerations, limitations of the research, and future research directions. Lastly, [Section 8](#) provides a final section of the paper that summarizes the major contributions of QEMES–ASHP and its replication framework of net-zero smart building energy management.

2 Literature Review

2.1 Building Energy Simulation and Multi-Physics Modelling

Conventional methods of building energy simulation have mainly been based on single-physics models, which are unable to adequately depict the multifaceted relationships that exist in the contemporary smart building. A thorough review of dynamic thermal simulation done by using building information modelling performed by Hosseini et al. [11] revealed the necessity of an integrated approach capable of modelling multi-domain interactions. Their results showed that traditional simulation models can often not be effective in the prediction of real-life energy performance because they make simplified assumptions and do not heavily interact with various physical processes.

Table 1: Comprehensive summary of research contributions of QEMES-ASHP framework.

Sl.No.	Contribution Area	Innovation	Methodology	Tools/Techniques	Validation	Results	Significance	Practical Impact	Policy/Research Implications
1	Quantum-Enhanced Multi-Physics Framework	Real-time coupling of thermal, electrical, airflow domains	Integration-first simulation paradigm	Variational Quantum Linear Solver (VQLS)	HPC + Quantum Hybrid Solver Benchmarks	20% faster convergence	First real-time quantum-enhanced building simulator	Improves design iteration speed	Enables adoption of quantum methods in building energy research
2	Fractal Temporal Modelling	Multi-scale demand forecasting	Fractional Brownian Motion + Bayesian Uncertainty	Stochastic modelling	12-month data across 5 climate zones	High predictive accuracy	Captures microsecond to seasonal cycles	Improves demand response planning	Supports resilient grid integration
3	AI-Driven Hybrid System Optimization	Dynamic solar-ASHP-PCM switching	Machine Learning-based hybrid control	RL & predictive control	IoT-sensor real-time data	31%-35% energy savings	Context-aware control decisions	Lowers operational energy cost	Guides hybrid system adoption in retrofits
4	Multi-Climate Validation	Diverse zone experimental testing	Field deployment in 5 climate types	IoT-based 150+ sensors	200 m ² testbed monitored 12 months	Statistically significant results ($p < 0.001$)	Demonstrates broad applicability	Proof of scalability	Supports policy for climate-zone specific codes
5	Computational Efficiency	Parallelizable solver integration	HPC-Quantum hybrid approach	Matrix decomposition acceleration	Solver runtime tests	20% computational gain	Reduces simulation bottleneck	Enables real-time BEMS	Encourages HPC + QC integration in industry
6	Comfort & Occupant-Centric Metrics	PMV control within ± 0.15	Thermal comfort modelling	Adaptive thermal control loop	PMV and PPD measurements	Comfort maintained in all zones	Enhances occupant well-being	Promotes human-centered building design	Could shape wellness certification criteria
7	Carbon Neutrality Impact	Life-cycle CO ₂ reduction analysis	LCA	LCA tools, embodied carbon databases	Energy vs. CO ₂ model coupling	30%-40% CO ₂ reduction	Direct link to carbon neutrality goals	Strengthens ESG reporting	Supports national dual-carbon roadmap

(Continued)

Table 1 (continued)									
SL.No.	Contribution Area	Innovation	Methodology	Tools/Techniques	Validation	Results	Significance	Practical Impact	Policy/Research Implications
8	Integration-First Paradigm	Single-platform modelling	Unified simulation architecture	Modular API	System architecture evaluation	Eliminates siloed modelling errors	Holistic performance analysis	Streamlines workflow for engineers	Encourages standardization
9	Practical Implementation Framework	Actionable design guidelines	Step-by-step deployment framework	Software-hardware integration protocol	Pilot deployment	Reduces adoption barriers	Improves technology transfer	Accelerates market readiness	Influences future building codes
10	Replicability & Scalability	Open framework	API-based extensibility	Cloud-ready architecture	Cross-validation on multiple datasets	High reproducibility	Ensures scalability across regions	Supports smart city rollouts	Promotes reproducible science

In recent years, much focus has been directed towards the development of multi-physics coupling frameworks. Han et al. [9] introduced a multi-layered reactor concept of calcium-based multi-physics coupled thermochemical heat storage, where simultaneous consideration of heat transfer, mass transfer, and chemical reaction rate is essential. Their work was more successful in providing high-quality performance due to detailed modelling of the mutual dependencies of the physical processes, which made the basis of the more advanced uses of building energy. Cheng et al. [6] also dealt with building and managing validated highly configurable multi-physics building models to analyze the sustainability of multi-energy systems in co-simulation configurations. In their study, the authors have evaluated the imperative relevance of real-time capability and validated modelling methods in real practice. But their model did not provide quantum-enhanced computational speed and fractal-based temporal modelling as used in the present paper.

The computational efficiency problem of multi-physics simulation has been noted to be one of the biggest bottlenecks to real-time applications. Investigating the role of parameter variance in design-operation gap in HVAC system control sequences by means of the simulation-dependent studies, Nomura et al. found that the traditional platform of computer platform calculus is not commonly suitable in giving timely feedback to adaptive control systems [21]. This drawback highlights the necessity to have sophisticated computing schemes, including quantum-enhanced solvers, in order to have real-time multi-physics simulation capabilities.

2.2 Phase Change Materials and Thermal Energy Storage Systems

Phase change materials have become a very essential element in the optimization of building energy, and provide a huge opportunity because they can be thermally regulated and stored. The viewpoint of PCM as passive systems simulated by Aghoei et al. [1] in envelopes of opaque buildings proved the potential of significant energy saving. Their efforts set the theoretical basis of PCM integration but did not include the capability to fully couple and optimize multi-physics in real-time. Assareh et al. [5] performed a comprehensive research on the application of PCM in zero-energy buildings with a focus on the integration of PCM with combined cooling, heating, and power systems on the basis of air source heat pump energy in Canada and the UAE. Their findings found that there were variations in performance depending on the climate, and adaptive control mechanisms must be developed that can control system set-up according to the local environmental conditions.

Rahmanian et al. have investigated advanced PCM applications [24] and came up with a nanofluid-PCM heat sink that could be used in building-integrated concentrated photovoltaic systems that are capable of storing and recovering thermal energy. This was limited to certain applications without building scale integration, and as evidenced by their work, hybrid renewable energy systems were possible. A thorough review of life cycle assessment of thermal energy storage in building application by Hayatina et al. [10] revealed the advantages of PCM systems to the environment and the economics of PCM systems. They also conducted an analysis noting the need to remember long-term sustainability effects, which is to be congruent with the life-cycle assessment methodology.

2.3 Artificial Intelligence and Machine Learning in Building Energy Management

The application of artificial intelligence in energy management in buildings has demonstrated an impressive future of optimizing energy use and enhancing the performance of the system. Khan et al. [15] created a very vital artificial intelligence-based model that predicts power consumption and power generation in an intelligent building energy management system and demonstrated a considerable level of improvement in predicting outcomes. However, they narrowed down their method to forecasting without the real-time multi-physics interactions and adaptive control. Lee et al. [17] explored machine learning applications in

thermal energy storage and experimentally analyzed AI-based model predictive control in various conditions of cooling loads. Their study revealed that the AI-driven control could be effective, but only to a few thermal systems, which were not integrated extensively across different building subsystems.

Mirjalili et al. [19] performed a comparative analysis of machine learning and deep learning as approaches to predict the energy balance in hybrid building-renewable energy systems as well. Their review indicated that deep learning methods tend to be utilized more effectively than other machine learning models, especially in intricate multi-variable prediction problems. Nonetheless, their effort did not imply quantification of uncertainty that underlines a credible building energy management. Na and Wang [20] have also investigated the use of the Bayesian approach on the construction of an energy system by creating an urban-scale energy model to calibrate building energy use of space heating in Beijing. Their Bayesian approach offered a solid quantification of uncertainty that formed the theoretical basis of the Bayesian uncertainty quantification aspect of the QEMES-ASHP framework.

The scalability of AI-based solutions that are developed by Selvaraj et al. [26] involves the development of smart building energy management and monitoring systems in smart cities based on artificial intelligence. Their authors also placed a strong emphasis on the significance of integration of IoT and real-time monitoring, which coincides with the IoT-instrumented validation approach that will be used in the present study.

2.4 Renewable Energy Integration and Hybrid Systems

Renewable energy systems in buildings have become more complicated, and thus complex optimization strategies are needed to ensure the highest efficiency and reduce costs as much as possible. Elaouzy and El Fadar [7] explored building-integrated photovoltaic, photovoltaic thermal, air source heat pump, and green roof systems and found that large amounts of energy can be saved when this is done correctly. Nevertheless, their operation was not dynamically optimized or adaptive control in real time. Perrella et al. have conducted extensive research on solar-assisted heat pump systems [22] and examined the significance of proper control measures to be used in exploiting solar sources with electric and thermal storage. Their study showed that smart control algorithms were quite important, but they were only restricted to certain system configurations without modelling full multi-physics.

Qiu et al. [23] have explored the optimization of integrated systems such as photovoltaic/thermal systems and air source heat pump systems to supply energy in cold regions to buildings. Their implementation delivered high energy saving by optimization of the system, but without quantum-improved calculations and fractal-based temporal modelling as developed in the present study. Aneli et al. [4] examined the way that solar-assisted thermal and electrical storage heat pumps enhance residential buildings' energy self-sufficiency. They also focused their research on the role of storage systems to integrate renewable energy, but omitted the complicated switching algorithms, which are needed to effectively run hybrid systems.

Wang et al. [30] studied the performance and optimization of new systems of solar-air source heat pump building energy supply that are equipped with an energy storage system. Their efforts showed that hybrid renewable energy schemes were feasible, but not extensively tested in multi-climate and quantum-enhanced optimization.

2.5 Quantum Computing Applications in Energy Systems

Quantum computing in energy systems is an emerging area that has promising potential in addressing computationally intensive optimization problems. Ajagekar and You [2] proposed a variational quantum

circuit-based demand response in buildings using a hybrid quantum-classical approach. Their experiment showed that quantum-enhanced methods could be used to construct energy applications, but only on the demand response without extensive multi-physics modelling. Wang et al. [28] have studied the recent advances in quantum-enhanced energy systems, where they created a quantum-enhanced predictive degradation pathway optimization of photovoltaic storage systems by using hybrid quantum-classical methods. Their study reached high results in terms of the system durability and performance due to quantum optimization, but managed to target the field of PV systems without integrating schemes on the building scale.

The possibilities of quantum application to specialized building applications are also evidenced by the research by Wang et al. [29] on quantum-enhanced forecasting and optimal scheduling of energy management in photovoltaic greenhouses. Nevertheless, they could only be used in certain agricultural applications without an integrated system of building energy.

Variational quantum linear solvers have their theoretical basis in the literature of quantum computing and have been shown to accelerate the solving of large-scale linear systems that are the basis of multi-physics simulations. Yet, applying VQLS to building energy simulation has not been studied in practice, which is one of the main research gaps that the present research fills.

2.6 Building Performance Evaluation and Climate Considerations

Climate-sensitive design approaches have been widely examined in various geographical locations. The study by Kaihou et al. [13] examined the impact of the climate-responsive design on the hot and dry Algerian South regions' thermo and energy performance using simulative studies. They focused on the significance of climate-specific optimization, but their work was restricted to the conditions of a certain region and was not extensively tested over a variety of climates. Kalwry and Atakara [14] have examined the design strategies used to make high-rise buildings' facades energy efficient by examining sustainable development strategies that are applicable in reducing energy consumption. Their study has shown that there is a possibility of using sophisticated facade systems without integration with building energy management systems.

The studies of technological progress and issues of the facade systems of the buildings based on the principles of sustainability in the current design practice were considered by Fernando et al. [8]. They found that there exist serious discrepancies between design intentions and real performance, and that sophisticated simulation tools that can predict performance are needed. Sood et al. [27] simulated the effects of occupancy on the energy consumption of archetypes of multi-scale residence buildings [31–33]. Their study has shown the significance of occupancy modelling to precise energy prediction, but has not mentioned the temporal modelling approaches based on the fractal, which is necessary to achieve multi-scale demand fluctuations.

2.7 Research Gaps and Limitations of Current Approaches

The overall analysis of literature allows for the finding of various research gaps that restrict the efficiency of existing building energy simulation and optimization strategies:

Most current methods usually treat thermal, electrical, and fluid dynamics separately without considering their interactions with each other, and these interactions have a high impact on the overall system behavior. Adaptive control cannot be implemented effectively since there are no real-time multi-physics coupling capabilities [34]. The classical simulation techniques have serious calculation constraints that do not allow real-time working, especially when it comes to multi-physics problems that have large-scale matrix solutions [35]. Existing technologies do not have quantum-enhanced computational acceleration protocols. Traditional simulation models adopt a consistent time discretization that does not resolve the

fractal character of energy demand patterns at several time scales. The lack of complex methods of time modelling restricts predictability and the effectiveness of control [36].

As shown in Fig. 1, the following gaps are very powerful reasons to develop the QEMES-ASHP framework, which comprehensively manages all these limitations by using quantum-enhanced multi-physics modelling, fractal-based time modelling, extensive climate validation, and powerful uncertainty quantification in an integrated operational system. Variations in climate conditions or restricted geographical areas are also the common theme in most of the already available research, which is not fully validated across the different climate conditions. Such a restriction affects the wide generalizability of suggested solutions. The existing AI-based building energy management technologies do not have serious uncertainty quantification tools, and are not designed to operate in the critical infrastructure environment, where reliability is a very important key requirement. Current strategies normally deal with individual elements or subsystems without taking into consideration how the hybrid renewable energy systems such as solar-ASHP-PCM would work together. The absence of detailed optimization structures restricts the possibilities of efficiency gains at the system level.




Figure 1: Identified limitations of existing building energy simulation approaches and the need for an integrated real-time framework.

In the majority of studies, there are no quantum-enhanced optimization methods, as Table 2 shows. There are some incomplete multi-physics interactions in building energy studies [37]. There is a lack of emphasis on the integration of different thermal utilization methods, and also some demands for sophisticated simulation techniques with quantum and classical methods [38,39]. There is a less comprehensive attitude towards the optimization of the energy system [40].

Table 2: Overview of existing studies and comparative context for QEMES–ASHP framework [1–30].

Sl. No.	Author(s) & Year	Study Focus	Methodology Applied	Key Technology	Building Type	Energy System	Main Findings	Research Gap	Study Contribution
1	Aghoei et al. (2024)	PCM passive systems	Simulation-based analysis	Phase change materials	Opaque building envelope	Thermal storage	Enhanced thermal performance	Limited multi-physics coupling	PCM integration methodology
2	Ajagekar & You (2024)	Quantum demand response	Variational quantum circuits	Hybrid quantum-classical	Buildings general	Demand response	Quantum optimization benefits	No thermal systems	Quantum building applications
3	Amani (2024)	Thermal insulation optimization	Simulation-based design	Optimal thermal insulation	Residential buildings	Passive systems	Minimized energy consumption	Single parameter focus	Insulation design framework
4	Aneli et al. (2023)	Energy self-sufficiency	Solar-assisted systems	Heat pumps storage	Residential buildings	Solar thermal electrical	Improved self-sufficiency	Limited integration analysis	Storage system combination
5	Assareh et al. (2024)	Zero-energy buildings	PCM CCHP systems	Air source heat pump energy	Zero-energy buildings	CCHP ASHP	Regional performance variation	Limited quantum enhancement	PCM ASHP integration
6	Cheng et al. (2025)	Multi-physics building models	Co-simulation setup	Validated configurable models	Multi-energy systems	Various energy systems	Enhanced model validation	No quantum integration	Multi-physics modelling framework
7	Elaouzy & El Fadar (2023)	Integrated renewable systems	Building-integrated systems	PV thermal systems	Buildings general	Renewable energy	System performance investigation	Limited optimization approach	Integrated system analysis
8	Fernando et al. (2023)	Sustainable façade systems	Technological advancement study	Façade system design	Sustainable buildings	Façade technologies	Current design challenges	Limited energy analysis	Façade sustainability framework
9	Han et al. (2022)	Thermochemical heat storage	Multi-physics coupling	Calcium-based storage	Energy storage	Thermal storage	Multi-layered reactor design	No building integration	Thermochemical storage design
10	Hayatuna et al. (2023)	Thermal energy storage	Life cycle assessment	TES building applications	Building applications	Thermal energy storage	LCA methodology review	Limited simulation integration	TES lifecycle framework
11	Hosseini et al. (2021)	Dynamic thermal simulation	Building information modelling	BIM-based simulation	Buildings general	Various systems	BIM simulation advantages	Limited quantum applications	BIM thermal simulation

(Continued)

Table 2 (continued)

Sl. No.	Author(s) & Year	Study Focus	Methodology Applied	Key Technology	Building Type	Energy System	Main Findings	Research Gap	Study Contribution
12	Hu et al. (2023)	Radiant cooling systems	Heat transfer review	Radiant cooling technology	Buildings general	Radiant cooling	Heat transfer mechanisms	No optimization focus	Radiant cooling analysis
13	Kaihoul et al. (2021)	Climate-responsive design	Simulation-based study	Climate adaptation strategies	Hot-dry climate	Various systems	Climate design impact	Regional limitation	Climate response framework
14	Kalwry & Atakara (2025)	High-rise façade efficiency	Energy-efficient strategies	Sustainable façade design	High-rise buildings	Façade systems	Energy consumption reduction	Limited system integration	Façade efficiency strategies
15	Khan et al. (2023)	AI energy management	AI-based framework	Power forecasting	Buildings general	Energy management	AI forecasting accuracy	No quantum enhancement	AI energy framework
16	Lam et al. (2022)	Smart building management	SBMS commercial buildings	Smart management systems	Commercial buildings	Building management	Key SBMS attributes	Limited thermal focus	SBMS framework
17	Lee et al. (2022)	AI predictive control	Experimental analysis	Model predictive control	Buildings general	Thermal energy storage	AI control effectiveness	Limited quantum integration	AI thermal control
18	Liao et al. (2022)	Radiant ceiling heating	Experimental study	Radiant heating systems	Different room types	Radiant heating	Energy thermal performance	Limited optimization	Radiant heating analysis
19	Mirjalili et al. (2023)	ML energy prediction	Machine learning comparison	Deep learning methods	Hybrid renewable buildings	Building-renewable systems	ML prediction accuracy	No quantum methods	ML energy prediction
20	Na & Wang (2022)	Energy consumption calibration	Bayesian approach	Urban-scale energy model	Beijing buildings	Space heating	Model calibration improvement	Limited scope	Bayesian calibration framework
21	Nomura et al. (2024)	HVAC control sequences	Simulation-based study	Parameter variance analysis	Buildings general	HVAC systems	Design-operation gap identification	No quantum optimization	HVAC parameter analysis
22	Perrella et al. (2024)	Solar-assisted heat pumps	Electric thermal storage	Appropriate control strategies	Buildings general	Solar heat pump	Control strategy importance	Limited integration analysis	Solar storage control

(Continued)

Table 2 (continued)

Sl. No.	Author(s) & Year	Study Focus	Methodology Applied	Key Technology	Building Type	Energy System	Main Findings	Research Gap	Study Contribution
23	Qiu et al. (2023)	Integrated system optimization	PV thermal systems	Air source systems	Cold area buildings	PV-ASHP systems	System optimization benefits	No quantum enhancement	Integrated system optimization
24	Rahmanian et al. (2021)	Nanofluid-PCM systems	Building integrated PV	Concentrated photovoltaic	Buildings general	Thermal storage recovery	Heat sink performance	Limited building integration	Nanofluid PCM integration
25	Roodkoly et al. (2024)	ANN energy prediction	Simulation-based framework	Artificial neural networks	Office buildings	Energy consumption	ANN prediction accuracy	Limited thermal analysis	ANN energy framework
26	Selvaraj et al. (2023)	Smart energy monitoring	AI-based management	Artificial intelligence	Smart buildings	Energy management	AI monitoring effectiveness	No quantum integration	AI monitoring framework
27	Sood et al. (2023)	Occupancy energy impact	Simulation-based evaluation	Multi-scale building archetypes	Residential buildings	Various systems	Occupancy consumption relationship	Limited optimization focus	Occupancy impact analysis
28	Wang et al. (2025)	Quantum PV optimization	Quantum-enhanced degradation	Hybrid quantum-classical	PV storage systems	Photovoltaic storage	Quantum optimization benefits	Limited building integration	Quantum PV framework
29	Wang et al. (2025)	Quantum energy forecasting	Quantum-enhanced scheduling	Optimal scheduling	Photovoltaic greenhouses	PV energy management	Quantum forecasting accuracy	Building application limited	Quantum forecasting framework
30	Wang et al. (2022)	Solar-ASHP pumps	Novel energy systems	Energy storage optimization	Buildings general	Solar air source heat pump	System performance optimization	No quantum enhancement	Solar ASHP optimization

3.1 QEMES Framework Overview

The QEMES–ASHP framework, titled “Integration-First Multi-Physics Simulation Paradigm”, is designed to model and optimize complex building energy systems by simultaneously solving thermal, electrical, and airflow dynamics while leveraging AI for real-time control as portrayed in Fig. 3.




Figure 3: QEMES-ASHP overall framework.

The system incorporates several enhanced elements: a quantum-enhanced linear solver (VQLS) to effectively behave with ill-conditioned blocks of matrices, an AI Controller integrating reinforcement learning (RL) with a fallback Model Predictive Control (MPC), and fractal load modelling based on fractional Brownian motion (fBm) to forecast multi-scale temporal variations in building energy demand. Furthermore, the system is based on a high-density of more than 150 IoT sensors to check temperature, humidity, occupancy, photovoltaic generation, thermal energy storage (TES), phase change materials (PCM), and air source heat pump (ASHP) modules. This network of dense sensors allows for monitoring the conditions in multi-zone buildings correctly and supplying the AI controller with highly dense data to manage energy consumption in real time. The framework explains its complexity by aiming to achieve over 95% energy efficiency in complex building operation, far higher than simpler, more traditional energy conservation methods that typically reach at most 80% efficiency. Communications (TLS/HTTPS) and secure local storage protocols are used to keep data protected and ensure that the data transfer is reliable and secure. QEMES–ASHP is specifically suited for office, residential, and industrial buildings, particularly those that combine solar-ASHP-TES/PCM configurations and require multi-zone control. It is new because of real-time connection of the thermal, electric, and air movement, the hybrid AI-driven control switching, and the selective use of quantum-enhanced linear solvers to compute computationally challenging problems. A typical workflow entails matrix assembly, execution of the quantum solver, update of the solution, and feedback provided by the AI controller, which depicts the hybrid strategy of the computational approach of the system. Although the strength of quantum computing, AI, fractal modelling, and multi-physics simulation is promising, it is still necessary to clearly measure the individual contribution of each of the above elements to the reported 31%–35% reduction in energy, but the aggregate benefits are significant and reflect the ability of the proposed approach to deliver a highly efficient smart building management.

Data Collection & Preprocessing

A systematic, multi-step procedure was used for data collection and preprocessing in the QEMES-ASHP experimental framework to guarantee high-quality, trustworthy data appropriate for sophisticated multi-physics and AI-driven analysis. In order to continuously monitor temperature, relative humidity, airflow, occupancy, photovoltaic generation, ASHP module performance, and thermal storage system states, more than 150 Internet of Things (IoT) sensors were placed throughout all building zones over the course of a year. To preserve data integrity, the procedure combined automated and manual validation techniques, as shown in Fig. 4:




Figure 4: QEMES-ASHP—data collection and pre-processing steps.

Step 1: Sensor Deployment and Configuration

In order to record spatial heterogeneity within each building zone, such as high-occupancy areas, areas close to HVAC diffusers, and areas next to TES/PCM/ASHP systems, sensors were placed strategically. Every sensor was set up to collect high-frequency data at intervals of one minute for energy consumption data and one hertz (Hz) for transient thermal and airflow measurements. WiFi, Zigbee, and LoRaWAN were among the communication protocols that provided dependable, low-latency transmission to the central data server.

Step 2: Continuous Monitoring and Logging

Secure TLS/HTTPS communication was used to log data in a cloud-based system. In the event of a network outage, data persistence was guaranteed by redundant local storage. Incoming data streams were validated by automated scripts, which also marked unusual readings for additional examination. The raw measurements were accompanied by metadata, including the timestamp, sensor ID, and calibration coefficients.

Step 3: Calibration and Drift Correction

The initial calibration of the sensors was done in accordance with the manufacturer's instructions, and seasonal drift was adjusted for every three months. Sensor readings were continuously modified by drift correction algorithms using reference measurements from precise instruments positioned in each zone. These algorithms ensured long-term measurement accuracy by accounting for environmental changes like variations in temperature and humidity.

Step 4: Outlier Detection and Removal

To detect anomalous measurements brought on by sensor noise, transient communication errors, or outside disturbances, statistical techniques such as z-score thresholds and interquartile range (IQR) analysis were used. To avoid bias in AI model training and system assessment, identified outliers were either eliminated from the dataset or corrected using nearby temporal data.

Step 5: Missing Data Imputation

A hybrid imputation technique was used to fill in occasional data gaps brought on by network problems or sensor outages. While longer gaps were filled using predictive models based on correlated sensor measurements within the same zone or similar environmental conditions, short gaps (less than five minutes) were linearly interpolated. This reduced artificial distortion while preserving continuity in time-series datasets.

Step 6: Normalization and Standardization

To make training AI controllers and multi-physics simulations easier, all sensor readings were scaled to comparable ranges and normalized to uniform units. To lessen the impact of seasonal variation and sensor heterogeneity, temperature, humidity, and energy data were standardized in relation to reference conditions.

Step 7: Data Quality Verification and Documentation

At the end of each month, both automated and manual verification checks were performed, which include cross-validation with redundant sensors, consistency checks across adjacent zones, as well as comparison with weather station data. Transparency and reproducibility were thoroughly ensured by meticulously documenting all preprocessing steps, modifications, as well as anomalies in a data log.

As [Fig. 5](#) illustrates, the flow combines classical simulation for system state estimation with quantum solvers for rapid optimization of control variables. Iterative feedback loops enable real-time scheduling of thermal, electrical, airflow, and ASHP systems for peak-load reduction and cost savings (Algorithm 1).




Figure 5: Hybrid quantum-classical control flow for QEMES-ASHP energy optimization.

Pseudocode

Algorithm 1: QEMES energy optimization

Input: Sensordata (Temperature, Humidity, Occupancy, PV, TES, PCM, ASHP)

Output: Optimizedcontrolactions (HVAC, TES, PCM, ASHPsetpoints)

1: *InitializeAIController (RL + MPCfallback)*

2: *InitializeQuantumSolver (VQLS) for ill – conditionedmatrixblocks*

3: *Deploy IoT sensors across building zones*

4: *Preprocess sensor data:*

– *Calibration & drift correction*

– *Outlier removal*

– *Missing data imputation*

– *Normalization/standardization*

5: *loop (every control cycle, e.g., 1 min thermal, 1 s electrical, 10 ms air flow)*

a. *Acquire real – time sensor data*

b. *Update multi – physics simulation (thermal + electrical + air flow + ASHP)*

c. *Assemble system matrices*

d. *if matrix is ill – conditioned then*

Solve using VQLS or classical solver

e. *AI Controller computes optimal actions (RL)*

f. *if RL fails or thresholds exceeded then*

Apply MPC fallback

g. *Apply control actions to HVAC, TES, PCM, ASHP*

h. *Log data & compute performance metrics*

6: *end loop*

7: *Evaluate annual energy savings, peak load reduction, comfort, and NPV*

3.2 Theoretical Foundation

QEMES–ASHP’s theoretical underpinnings include probabilistic uncertainty quantification, fractal-based temporal prediction, quantum computation, and multi-physics modelling. Heat transfer, electrical load behavior, airflow patterns, and ASHP thermal exchange throughout the building are all thoroughly captured by the governing equations, which comprise thermal, electrical, as well as fluid-dynamics models. Variational Quantum Linear Solvers (VQLS) represent the selective application of quantum computation that speeds up computation without sacrificing reliability; they are applied only to ill-conditioned matrix blocks where classical solvers converge slowly. Fractional Brownian motion (fBm) captures temporal variability in energy demand and occupancy, enabling multi-scale forecasting that is essential for efficiently coordinating TES, PCM, and ASHP operations. Bayesian uncertainty quantification offers probabilistic evaluations of system performance and robustness, providing a means to quantify and manage uncertainty in predictions and control actions. The multi-physics and stochastic nature of building energy systems are comprehensively addressed by this integrated theoretical framework, which ensures that QEMES–ASHP can deliver precise, dependable, and optimal control decisions in real time.

3.3 Quantum Enhancement

Variational Quantum Linear Solver (VQLS)

By using variational quantum algorithms, the quantum-enhancement component of QEMES-ASHP accelerates specific computational bottlenecks in the multi-physics simulation environment. The principal quantum technique used is the Variational Quantum Linear Solver (VQLS), which is designed to solve linear systems of the form $Ax = b$ for matrix sizes up to $N \leq 1024$. The QEMES-ASHP framework targets computations where potential quantum acceleration could be significant by applying VQLS selectively to ill-conditioned sub-blocks in which classical sparse solvers tend to converge slowly. Implementation employs an IBM Q 16-qubit processor, together with error-mitigation techniques such as zero-noise extrapolation and decoherence-aware scheduling, to ensure that short-term hardware noise does not degrade solution quality. For reliability, a classical solver is retained as a fallback for any sub-blocks where the quantum solver may fail or produce insufficiently accurate results.

It is important to note that the reported 20% computational speed-up using a 16-qubit processor should be interpreted cautiously. The qubit count, coherence time, and gate fidelity of current quantum hardware remain limited, and very large, fault-tolerant quantum systems are typically required to achieve true real-world quantum advantage for linear-algebra problems. The QEMES-ASHP framework therefore acknowledges the speculative nature of near-term quantum gains; the observed speed-up is based on idealized benchmarking conditions. To contextualize these claims, comprehensive benchmarking data comparing quantum and classical sub-block solutions—including runtime statistics, error margins, and convergence behavior—are presented in later sections.

Timing & Real-Time Considerations

Table 3 summarizes the latency requirements for each major component of the QEMES-ASHP pipeline from sensor acquisition to control decision execution. The goal is to maintain sub-second end-to-end responsiveness, ensuring feasibility for real-time building energy optimization.

Table 3: Timing and real-time performance targets for QEMES-ASHP framework components.

Component	Target Latency	Justification
Sensor Acquisition	50 ms	Rapid multi-zone monitoring (research)
Matrix Assembly	120 ms	Sparse block formation
Quantum Solver	180–250 ms	Applied only to ill-conditioned blocks
RL Inference	80 ms	Multi-zone and ASHP control decision-making
Network Overhead	20–30 ms	Local communication
Total	≤ 500 ms	Sub-second target explored; practical systems may operate at 15-min intervals

The QEMES-ASHP system integrates sensor acquisition, matrix assembly, quantum computation, AI inference, and network communication within a total target latency of ≤ 500 ms. In practice, the system operates with sub-second computational cycles, enabling real-time optimization of solar-ASHP-TES-PCM hybrid systems. Sparse matrix assembly is allotted 120 ms, while sensor acquisition is anticipated to occur within 50 ms to guarantee rapid monitoring of thermal, electrical, and ASHP-driven multi-zone building conditions. Given that current quantum hardware limits full real-time speedup, the quantum solver is expected to execute in 180–250 ms for the ill-conditioned matrix blocks. For AI-driven control

actions, 80 ms is allocated for reinforcement learning (RL) inference, while 20–30 ms accounts for local communication overhead.

Although these timings demonstrate a sub-second control loop for research evaluation, practical building management systems may operate at coarser intervals (e.g., every 15 min) without significantly reducing optimization performance. The selective application of VQLS ensures that the framework remains robust and computationally feasible, and the quantum advantage is employed only when classical sparse solvers exhibit slow convergence. The QEMES–ASHP framework thus achieves a practical balance between leveraging emerging quantum capabilities and maintaining dependable, real-time performance in intelligent building energy optimization.

3.4 Multi-Physics Coupling Methodology

The QEMES–ASHP framework achieves a tight integration of thermal, electrical, airflow, and ASHP dynamics through a coupled multi-physics simulation approach. The thermal behaviour of the building is modelled using the standard heat transfer Eq. (1):

$$\rho c_p \frac{\partial T}{\partial t} = \nabla \cdot (k \nabla T) + Q_{HVAC} + Q_{PCM} + Q_{ASHP} \dots \quad (1)$$

where ρ is the air density, c_p is the specific heat capacity, k is the thermal conductivity, and Q_{HVAC} and Q_{PCM} represent heat inputs from HVAC systems and phase change materials, respectively. This formulation thoroughly allows QEMES-ASHP to capture both conduction and active thermal management contributions, which are very essential for accurate prediction of indoor temperatures across multiple zones.

The electrical load of the building is modelled as a function of voltage, current, and temperature, $P(t) = f(V, I, T)$, to account for dynamic variations in HVAC and ASHP power draw, lighting, and equipment loads. Integrating this electrical model with the thermal system thoroughly ensures that energy consumption is calculated in a physically consistent manner, which also allows for very precise evaluation of building energy performance under different control strategies.

1. Thermal Modelling (Heat Transfer Equation):

The thermal behaviour of the building is governed by the following heat transfer equation:

$$\frac{\partial T}{\partial t} = \alpha \nabla^2 T + \frac{Q_{in}}{\rho c_p} - \frac{Q_{out}}{\rho c_p}$$

where (T) is the temperature at a given point in the building, (α) is the thermal diffusivity, $(\nabla^2 T)$ is the Laplacian operator that accounts for heat conduction, (Q_{in}) and (Q_{out}) are the heat input and output due to HVAC systems and environmental factors, (ρ) is the density of the material, (c_p) is the specific heat capacity of the building materials. This equation captures the thermal dynamics of the building and will be solved using a finite difference method to discretize time and space.

2. Electrical Load Modelling:

The electrical consumption within the building, particularly the HVAC system and air source heat pump (ASHP), is modelled using the following equation:

$$P(t) = V(t) I(t)$$

where $(P(t))$ is the power consumption at time (t) , $(V(t))$ is the voltage applied to the system at time (t) , $(I(t))$ is the current drawn by the electrical components.

The voltage and current are functions of time, and their variations depend on the system's load and environmental conditions. These equations are solved using standard circuit simulation techniques such as Kirchhoff's laws and mesh analysis.

3. Fluid Dynamics (Airflow Modelling):

The airflow dynamics in the building, which directly affect both the thermal comfort and energy consumption, are modelled using the Navier-Stokes equations:

$$\rho \left(\frac{\partial \mathbf{v}}{\partial t} + \mathbf{v} \cdot \nabla \mathbf{v} \right) = -\nabla P + \mu \nabla^2 \mathbf{v} + \mathbf{F}$$

where ($\mathbf{v}$) is the velocity vector of the airflow, (ρ) is the air density, (P) is the pressure field, (μ) is the dynamic viscosity of the air, ($\mathbf{F}$) represents any external forces such as fans or natural ventilation. This equation governs the airflow throughout the building and will be solved using computational fluid dynamics (CFD) techniques. We will employ finite element or finite volume methods to discretize the equations.

4. Coupling and Solution Process:

The thermal, electrical, and fluid dynamics models are coupled together in an iterative process as follows:

1. Indoor temperature distribution is also the output of the thermal model to be used in the electrical load model (HVAC and ASHP consumption).
2. Electrical model varies the power consumption depending on the variation in temperatures and demand of the system.
3. The fluid dynamics model recalculates the airflow distribution of the building which also affects the thermal and electrical models through the factor of heat transfer and system efficiency.

A semi-implicit time-stepping system of equations is used, thus making the system stable and accurate. The thermal, electrical and fluid models are revised each time step to capture the prevailing conditions of the system.

Our framework employs the Fractional Brownian Motion (fBm) model to model the self-similarity and long-range dependence which is often seen in the time dependence of building energy consumption patterns. Unlike the traditional models, which can assume that the demand is associated with simple random walk, fBm gives us an opportunity to model the energy variations that are characterized by memory effects, i. e., the previous energy consumption determines the future behaviour. The physical relationship between the fBm model and the dynamic building load is the variation of energy demand with the changes in the time scales i.e., hourly, daily, and seasonal cycles. The fBm model will be able to predict the propagation and influence of small variations in environmental factors (e.g., outdoor temperature, humidity, occupancy) on thermal loads and electrical demands within the building over time. It is a model that is especially helpful in forecasting unpredictable changes in energy demand that is essential to optimize the functionality of HVAC systems, air-source heat pumps (ASHP), and thermal storage units in real-time. The model can capture these dynamic patterns, thereby allowing more precise forecasting and control decisions.

The Variational Quantum Linear Solver (VQLS), which manages the most computationally intensive sub-blocks in the coupled matrix system, is used to couple these four physics domains. Real-time modifications to HVAC/ASHP setpoints, TES/PCM activation, and airflow modulation are reliably incorporated into the simulation loop through feedback from the AI controller. Adaptive time-stepping is employed by QEMES-ASHP to balance the various temporal scales of the coupled systems: thermal dynamics are updated approximately every minute, electrical dynamics every second, and airflow dynamics every 10 ms. This multi-scale approach ensures numerical stability while maintaining computational efficiency. Its accuracy and resilience are ensured by enforcing convergence criteria below 10^{-5} and verifying Courant–Friedrichs–Lewy (CFL) conditions at each iteration.

3.5 AI Controller Design

The QEMES–ASHP framework employs a hybrid AI control strategy that combines Reinforcement Learning (RL) for adaptive, multi-zone energy management with Model Predictive Control (MPC) as a safety fallback. This approach ensures both real-time optimization and operational reliability while accommodating the complex dynamics of thermal, electrical, airflow, and ASHP systems in smart buildings.

Specific AI/ML Algorithms

Reinforcement Learning, more specifically a Deep Q-Network (DQN), is the main AI algorithm used; however, depending on the required control horizon and available computing power, Proximal Policy Optimization (PPO) or other policy-gradient techniques may also be applied. RL can handle high-dimensional, multi-zone control problems and learn optimal policies from synthetic and historical data without requiring an explicit model of the building dynamics. To ensure safety in extreme weather or sensor failure conditions, the MPC component serves as a backup. Nonlinear or robust MPC formulations can be used for more complex scenarios, while a linear variant is adopted here. RL outputs are prioritized during normal operation, and MPC intervenes when state deviations exceed preset thresholds (e.g., $\pm 2^\circ\text{C}$ temperature or $\pm 5\%$ relative humidity).

State and Action Spaces

The system is formulated as a Markov Decision Process (MDP) with the following components:

- **State Space (S):**

$$S = \{T_{\text{zones}}, RH, occupancy, solarirradiance, PCMstate, TESstate, ASHPstate\} \dots \quad (2)$$

The state space (Eq. (2)) captures thermal conditions, relative humidity, occupancy levels, solar input, and the operational states of TES, PCM, and ASHP systems across more than ten building zones.

- **Action Space (A):**

$$A = \{Setpointadjustments, TESactivation, PCMActivation, HVACmodulation, ASHPmodulation\} \dots \quad (3)$$

The action space (Eq. (3)) defines all controllable interventions within the building, including setpoint adjustments, TES activation, PCM activation, HVAC modulation, and ASHP modulation, enabling the AI to dynamically manage energy consumption. It defines all controllable interventions within the building, enabling the AI to modulate energy usage dynamically.

Reward/Objective Function

The RL agent is trained to maximize energy efficiency while maintaining comfort and minimizing costs, formalized as:

$$R = w_1 \cdot \text{Energy Reduction} - w_2 \cdot \text{Peak Load} - w_3 \cdot \text{Cost} \dots \quad (4)$$

where w_1, w_2, w_3 are weighting coefficients tuned to prioritize energy savings, peak demand reduction, and operational cost efficiency. Reward normalization ensures stable convergence during training.

Training Details

Training is carried out on an 8-GPU high-performance cluster using both synthetically generated and historical building data to cover diverse occupancy and climate conditions. Hyperparameters such as learning rate, discount factor, and batch size are optimized to balance convergence speed and policy robustness during a 72–120-h training cycle. The hybrid AI controller demonstrates strong performance

across more than ten building zones. MPC-enforced safety thresholds preserve occupant comfort by limiting extreme temperature or humidity fluctuations and allowing RL to explore optimal control strategies for HVAC, TES, PCM, and ASHP systems.

3.6 Fractal-Based Temporal Modelling

To capture the multi-scale temporal dynamics of energy demand in complex buildings, QEMES-ASHP employs a fractal-based load modelling approach using Fractional Brownian Motion (fBm). This enables accurate forecasting of thermal and electrical loads across multiple time scales, which is essential for coordinated operation of Thermal Energy Storage (TES), Phase Change Material (PCM), and ASHP systems.

The governing equation for the fractal-based temporal modelling is expressed as:

$$XH(t) = \int_0^t K_H(t, s) dB(s), \quad H = \text{Hurst exponent} \dots \quad (5)$$

where $XH(t)$ represents the stochastic load process, $K_H(t, s)$ is the kernel function encoding temporal correlations, and $B(s)$ is a standard Brownian motion. The Hurst exponent (H) is optimized for each building zone to capture long-term persistence or anti-persistence in load profiles, which thoroughly allows the model to adapt to different occupancy patterns, climate conditions, as well as system responses.

With only a 5%–8% overhead compared to the baseline multi-physics simulation, the computational cost of putting this fractal-based model into practice is negligible, and the predictive accuracy is greatly improved. Multi-scale load forecasting outperforms traditional time-series models such as LSTM and ARIMA, particularly when there is stochastic occupancy and variable weather. By integrating the fractal-based forecasts into a Bayesian framework, which thoroughly permits probabilistic load prediction with uncertainty quantification, predictive reliability is further enhanced. With this integration, the AI controller can make risk-aware decisions, optimize TES and PCM and ASHP operations, as well as account for possible variations in expected energy demand. The fractal-based temporal modelling provides a dependable, scalable, and computationally efficient approach for multi-horizon load forecasting, which directly supports the real-time, AI-driven, as well as quantum-enhanced control objectives of QEMES-ASHP.

3.7 System Integration & Fault Tolerance

To ensure continuous and reliable operation, QEMES-ASHP implements a comprehensive system integration and fault-tolerance framework. The architecture is designed to handle hardware, software, and communication failures without compromising energy optimization or occupant comfort.

Fault Handling Strategy

A hierarchical fallback approach is employed for all critical components:

- **Quantum Solver Unavailability:** If the Variational Quantum Linear Solver (VQLS) becomes unavailable due to hardware downtime or scheduling conflicts, the system automatically switches to a classical sparse solver, ensuring uninterrupted multi-physics computation.
- **Sensor Failures:** In the event of IoT sensor malfunction, missing or erroneous data is corrected through statistical imputation and real-time calibration adjustments, minimizing errors in AI-driven control actions.
- **ASHP Module Malfunction:** If the air-source heat pump communication or control fails, fallback load balancing is carried out through the HVAC/TES subsystems to preserve thermal comfort and system stability.

- **AI Controller Failures:** If the primary RL controller experiences instability or convergence issues, MPC takes over to maintain safe and reliable operation.

Communication and Latency

All inter-component communication is monitored to maintain latency under 30 ms, enabling near-real-time decision-making for multi-zone control, TES/PCM/ASHP coordination, and adaptive HVAC modulation.

Error Propagation and Sensitivity Analysis

To assess the impact of uncertainties in building parameters, sensor data, and environmental variations, Monte Carlo sampling is applied across all physics domains—thermal, electrical, airflow, and ASHP. This process allows:

- Identification of parameters most influencing energy consumption, comfort, and economic indicators such as NPV and payback period.
- Quantification of cumulative uncertainty, enabling the AI controller to account for deviations in real-time optimization.
- Robustness testing to ensure the integrated system maintains over 95% energy efficiency under realistic operational conditions.

This system integration and fault-tolerance framework ensures that QEMES–ASHP operates safely and reliably even under component failures or unexpected environmental changes, while preserving the predictive and optimization strengths of the quantum-enhanced, AI-driven, multi-physics paradigm.

3.8 Experimental Setup

With a 12-month monitoring period to account for seasonal variability, the experimental setup for QEMES–ASHP was created to thoroughly validate its performance under a variety of real-world conditions. To guarantee the generalizability of the results, experiments were carried out in five representative climate zones in China, involving multiple building types. In order to measure temperature, relative humidity, airflow, occupancy, photovoltaic generation, ASHP performance, and thermal storage system states, more than 150 Internet of Things sensors were installed in each building.

To ensure measurement accuracy throughout the year, drift correction procedures were implemented, and sensor calibration was conducted every three months. The experimental design was supported by a comprehensive statistical methodology that included power analysis to determine adequate sampling for detecting significant energy savings and comfort improvements, effect size estimation using Cohen's *d*, and multiple comparison correction through Bonferroni and Holm procedures. To further quantify uncertainty and ensure the robustness of performance metrics, 1000-iteration bootstrap confidence intervals were applied.

Model Accuracy Comparison:

The validation of the model was done against experimental data in the following ways in terms of accuracy:

Statistical Validation:

Root mean square error (RMSE) and mean absolute error (MAE) were determined between the model results and the real sensor values. These metrics of errors were employed to measure the difference between the predicted and observed energy consumption, thermal comfort, and system performance.

Comparative Performance:

The energy saving predictions and the peak load reduction predictions of the model were compared against the experimental data of the test buildings. A t -test of paired samples was used to examine the statistical significance of the differences between the model and the actual performance.

Confidence Intervals:

In order to test the strength of the model further, bootstrap confidence intervals of 1000 iterations were studied against the data of the experiment. The approach can give a probabilistic insight into the prediction accuracy of the model, which assists in measuring the uncertainty in the predictions of energy savings and comfort.

Effect Size Estimation:

The Cohen d method was used to approximate the effect size of significant energy savings and improvements of comfort. This is used to learn the practical importance of the model predictions as compared to the experimental outcomes.

3.9 Scalability & Commissioning

The QEMES-ASHP framework was designed to be scalable across buildings of all sizes, from compact 50 m² offices to large 5000 m² commercial or industrial complexes. It even supports district-level coordination among interconnected smart buildings. System parameters, such as the Hurst exponent for fractal-based temporal modelling and hyperparameters for the Reinforcement Learning controller, were specifically tuned for each climate zone to enable adaptive control under varying occupancy and environmental conditions. This guarantees optimal performance across diverse climates and building configurations.

To ensure highly accurate real-time performance and system dependability, a rigorous multi-step commissioning protocol was followed. Each IoT sensor and device was first configured and tested to confirm proper communication, calibration, and ASHP data synchronization. A one-week baseline data collection phase was then performed without active QEMES-ASHP intervention to capture the building's natural thermal, electrical, airflow, and occupancy dynamics. This baseline dataset was used to initialize the hybrid RL + MPC controller, ensuring a smooth and secure system startup.

After controller initialization, multi-physics validation was performed to confirm accurate coupling among the thermal, electrical, airflow, and ASHP models. Once parameters were tuned and end-to-end latency verified to be under 500 ms, the system met the sub-second decision-making requirements for TES/PCM/ASHP coordination and multi-zone HVAC control. Routine maintenance and recalibration were scheduled every three to six months to mitigate sensor drift, preserve data fidelity, and maintain control accuracy.

For compliance and compatibility with building management practices, QEMES-ASHP operations adhered to relevant standards and guidelines such as ASHRAE protocols and local building codes. This systematic approach to scalability and commissioning ensures consistent energy savings, comfort enhancement, and environmental performance across multiple building types and climates, supporting broad deployment of the QEMES-ASHP framework.

3.10 Ablation & Justification Studies

To measure the distinct contributions of the essential elements of QEMES, ablation studies were carried out. The complete QEMES-ASHP system, QEMES-ASHP without the quantum-enhanced linear solver, QEMES-ASHP without the Reinforcement Learning (RL) controller, and QEMES-ASHP without fractal-based temporal modelling were the four configurations that were assessed. Performance metrics such as net

present value (NPV), occupant comfort (PPD/PMV), peak load reduction (%), and annual energy savings (%) were noted for every configuration. To ensure thorough validation, two-sample *t*-tests with Bonferroni correction were used to assess the statistical significance of the differences in comparison to the entire QEMES-ASHP system. Table 4 provides a summary of the findings:

Table 4: Ablation studies.

Configuration	Energy (%)	Peak Load (%)	Comfort (PPD%)	NPV (\$/m ²)	<i>p</i> -Value
QEMES-ASHP	34.5	28.7	6.2	1847	–
No Quantum	30.2	24.1	6.5	1650	0.002
No RL	27.8	21.3	7.1	1575	<0.001
No Fractal	29.1	22.8	6.9	1602	0.001

To measure the contributions of the various QEMES-ASHP components, ablation studies were conducted. With a PPD of 6.2% and an NPV of \$1847/m², the entire system produced a 28.7% reduction in peak load and an annual energy savings of 34.5%. The significance of the solver for ill-conditioned matrix acceleration was thoroughly demonstrated by the reduction in energy savings to 30.2% and peak load reduction to 24.1% when the quantum-enhanced solver was excluded (*p* = 0.002). Eliminating the RL controller further reduced energy savings to 27.8% and raised PPD to 7.1%, which demonstrates the crucial function of AI-driven multi-zone control (<0.001). The impact of fractal-based temporal modelling on multi-scale load forecasting was demonstrated by the slight decline in comfort (PPD 6.9%) and energy performance (29.1%) that resulted from its omission. The integrated quantum, AI, and fractal components are thoroughly required for the best building energy performance, as confirmed by the *p*-values, which show statistically very significant differences when compared to the full QEMES-ASHP configuration.

The ablation study emphasizes the way that important fractal-based temporal modelling, AI-driven control, and quantum acceleration are key to reaching QEMES-ASHP's superior multi-criteria performance. Omitting RL lowers adaptive control efficacy across multi-zone operations, while removing the quantum solver affects computation speed and energy optimization for ill-conditioned matrix blocks. Comfort metrics and TES/PCM coordination are impacted when fractal temporal modelling is excluded because it reduces the accuracy of multi-scale load forecasting. The *p*-values validate the design decisions and support the integrated approach by confirming the statistical significance of these components' contributions. The quantum-enhanced solver accelerates the optimization process, enabling the Reinforcement Learning (RL) controller to explore the solution space more efficiently. Without the quantum solver, the RL controller performs slower, which leads to reduced energy savings and comfort. Similarly, the fractal-based temporal model improves the accuracy of multi-scale load forecasting. When this component is removed, the system's ability to predict fluctuations in energy demand becomes less accurate, slightly affecting both comfort (PPD) and energy savings. These interactions demonstrate that the integrated components—quantum solver, RL control, and fractal modelling—work together to optimize system performance.

3.11 Data Analysis & Statistical Validation

Data analysis and statistical validation of QEMES-ASHP outputs are carried out using a weighted multi-criteria scoring approach that integrates energy performance, peak demand reduction, thermal comfort, and economic benefits into a single performance index. The weighted score is defined as in Eq. (6).

$$\text{Score} = 0.4 \cdot E + 0.25 \cdot P + 0.2 \cdot C + 0.15 \cdot \text{EconScore} \quad (6)$$

here, E represents annual energy savings, P denotes peak-load reduction, C corresponds to comfort performance (PPD), and EconScore captures economic performance metrics such as NPV and payback. Weight coefficients (0.4, 0.25, 0.2, and 0.15) are assigned to emphasize energy and demand reduction while balancing comfort and financial efficiency.

To account for uncertainty arising from sensor inaccuracies, seasonal variations, and stochasticity in AI and ASHP control outputs, bootstrap resampling with 1000 iterations is employed to estimate 95% confidence intervals. Two-sample t -tests with Bonferroni correction are performed across energy, comfort, and economic indicators to verify statistical significance between QEMES–ASHP and baseline systems (e.g., GSHP-based or non-hybrid setups). All p -values are reported to confirm statistically significant improvements and validate the robustness of observed performance advantages.

3.12 Computational Cost & Practical Justification

Energy savings are compared to the computational cost in \$/kWh saved to assess the practical viability and computational overhead of the QEMES–ASHP framework. To capture rapid dynamics across the thermal, electrical, and ASHP domains, the system is configured to operate under standard building control intervals of 15 min, while a 30-s update interval is maintained during research and benchmarking to record transient variations in thermal–electrical coupling and ASHP operation.

As summarized in Table 5, the Reinforcement Learning (RL) controllers are retrained every 6 to 12 months to address operational drift and seasonal variability, following an initial training phase on one year of combined historical and synthetic data. The selective quantum solver, Variational Quantum Linear Solver (VQLS), is applied exclusively to ill-conditioned matrix sub-blocks to accelerate convergence in coupled thermal–electrical–airflow–ASHP systems. This hybridized computational scheme minimizes total processing cost while ensuring real-time response.

Routine latency benchmarks confirm sub-second responsiveness (≤ 500 ms per optimization loop), with only 12%–15% computational overhead relative to total system execution. The ASHP integration introduces negligible additional cost because control and thermodynamic feedback are embedded within the same hybrid AI-quantum computation loop. Hence, the QEMES–ASHP configuration achieves superior energy performance and cost efficiency without compromising responsiveness or scalability.

The QEMES–ASHP framework is fully compatible with existing Building Management Systems (BMS) and can be integrated into operational environments with minimal hardware modification. As shown in Table 6, this methodology ensures that QEMES–ASHP remains computationally efficient, economically viable, and deployable in real-world scenarios while delivering measurable gains in energy efficiency, comfort, and peak demand management.

Overall, the results confirm that QEMES–ASHP achieves statistically significant improvements in annual energy savings, peak-load reduction, and economic performance compared to baseline geothermal or conventional hybrid systems. These findings substantiate the framework's ability to provide a balanced integration of artificial intelligence, quantum acceleration, and ASHP-driven thermal optimization in next-generation smart building applications.

Table 5: Computational cost and parameters for QEMES-ASHP.

Parameter	Symbol/ Metric	Target Value	Computation Component	Cost per Cycle (\$)	Energy Saved per Cycle (kWh)	Cost per kWh Saved (\$/kWh)	Computational Overhead (%)	Practical Justification	Notes/Remarks
Sensor Acquisition Latency	$t_{\text{sensor}}_{\{\text{sensor}\}}$	50 ms	IoT Edge Devices	0.002	0.001	2.00	1.5%	Allows high-frequency zone monitoring to capture transient thermal dynamics.	Achieves near real-time sensing.
Matrix Assembly Time	$t_{\text{matrix}}_{\{\text{matrix}\}}$	120 ms	Preprocessing + Sparse Matrix Formulation	0.004	0.002	2.00	3.0%	Ensures accurate formation of coupled thermal-electrical- airflow equations before solving.	Parallelized for speed.
Quantum Solver Execution	$t_{\text{VQLS}}_{\{\text{VQLS}\}}$	180–250 ms	Variational Quantum Linear Solver (VQLS) + ASHP Thermal Coupling	0.012	0.010	1.20	8%–10%	Selectively accelerates ill-conditioned sub-blocks, improving convergence speed and solution accuracy.	Classical solver as fallback.
RL Inference Time	$t_{\text{RL}}_{\{\text{RL}\}}$	80 ms	DQN/PPO Controller for Multi-Zone HVAC-TES- PCM-ASHP Coordination	0.006	0.009	0.67	5.5%	Provides adaptive control and multi-zone energy optimization.	Prioritized over MPC under normal operation.
MPC Fallback Execution	$t_{\text{MPC}}_{\{\text{MPC}\}}$	≤100 ms	Linear MPC Controller	0.005	0.007	0.71	4.2%	Maintains safe operation when RL agent deviates beyond comfort thresholds.	Guarantees robustness.
Network Overhead	$t_{\text{net}}_{\{\text{net}\}}$	20–30 ms	Local Communication	0.001	0.0008	1.25	1.0%	Ensures reliable, low-latency communication across IoT nodes and BMS.	TLS/HTTPS encrypted.
Energy Reduction Achieved	$E_{\text{saving}}_{\{\text{saving}\}}$	34.5%	System-Wide	–	0.0345 (normalized per cycle)	–	–	Demonstrates superior performance compared to baseline (≤20%).	Statistically significant ($p < 0.05$).

(Continued)

Table 5 (continued)									
Parameter	Symbol/ Metric	Target Value	Computation Component	Cost per Cycle (\$)	Energy Saved per Cycle (kWh)	Cost per kWh Saved (\$/kWh)	Computational Overhead (%)	Practical Justification	Notes/Remarks
Peak Load Reduction	P_{red} {reduction} Production	28.7%	HVAC/TES/PCM/ASHP Actuation	-	-	-	-	Reduces grid stress, enhances resilience during peak hours.	Meets demand response goals.
Computational Cost vs. Benefit	C_{comp} {comp} Ccomp	≤\$0.05 per cycle	End-to-End	0.05	0.0345	1.45	12%–15%	Justified as net positive due to energy & cost savings.	Payback < 3 years.
Overall Cycle Latency	t_{cycle} {cycle} tcycle	≤500 ms	Entire QEMES Loop	-	-	-	100%	Enables near real-time hybrid quantum-classical optimization loop Optimized for TES/PCM/ASHP hybrid integration	Scalable to 15-min operational intervals for real deployments.

Table 6: Multi-metric performance evaluation of QEMES-ASHP framework against baseline systems.

Metric	Unit	Target Value	Achieved Value (QEMES)	Baseline Value	Relative Improvement (%)	Computation Cost (\$/kWh Saved)	Justification	Scalability Notes	Statistical Significance (p-Value)
Annual Energy Savings	%	≥30%	34.5	20.1	+71.6	0.12	Exceeds ASHRAE benchmarks, supports net-zero goals	Scales well across 50–5000 m ² buildings	<0.001
Peak Load Reduction	%	≥20%	28.7	16.3	+76.1	0.15	Reduces demand charges and grid stress	Effective in multi-zone HVAC configurations	0.002
Thermal Comfort (PPD)	%	≤10%	6.2	8.5	−27.1	N/A	Improved comfort drives occupant productivity	Maintains comfort even in extreme climate zones	0.004
Economic Benefit (NPV)	\$/m ²	≥1500	1847	1150	+60.6	N/A	Strong financial justification for deployment	Payback < 4 years for most buildings	<0.01
Computational Latency	ms	≤500	480	N/A	–	N/A	Meets near-real-time target for dynamic control	Allows 15-min control intervals for practical ops	Validated
AI Retraining Interval	Months	6–12	9	N/A	–	N/A	Periodic retraining ensures adaptability	Scales with building usage data growth	N/A
Quantum Solver Usage	% of Blocks	≤10%	7%	N/A	–	Slight cost overhead	Selective acceleration avoids overuse of quantum resources ASHP coupling supported under quantum–classical hybrid workflow	Future hardware upgrades reduce latency further	Benchmarking in Supplementary
Fractal Modelling Overhead	%	≤10%	5–8	N/A	–	Minimal	Low-cost improvement in forecasting accuracy	Works with ARIMA/LSTM fallback if disabled	N/A

(Continued)

Table 6 (continued)									
Metric	Unit	Target Value	Achieved Value (QEMES)	Baseline Value	Relative Improvement (%)	Computation Cost (\$/kWh Saved)	Justification	Scalability Notes	Statistical Significance (p-Value)
BMS Compatibility	-	Required	Fully Compatible	Partial	-	N/A	No major hardware changes needed. Integration validated with ASHP-enabled BMS modules.	Works with BACnet & Modbus protocols	Confirmed
Regulatory Compliance	-	ASHRAE 90.1/Local Codes	Compliant	Partial	-	N/A	Ensures legal readiness	Globally adaptable to ISO/IEC standards	Certified

4 Experimental Setup and Testbed Design

As Fig. 6 illustrates, the setup integrates real building sensor data, a multi-physics simulation engine, an AI-based controller, ASHP-integrated HVAC modules, and quantum solver components. Hybrid cloud–edge deployment ensures synchronized data flow and real-time feedback for validation across multiple building scales.




Figure 6: Experimental setup for QEMES framework evaluation.

4.1 Test Building Configuration

The experimental testbed is a 200 m² fully instrumented smart building designed to support high-fidelity multi-physics simulations encompassing airflow, electrical, and thermal dynamics. The configuration incorporates an Air Source Heat Pump (ASHP) integrated with Thermal Energy Storage (TES) and Phase Change Material (PCM) units to evaluate hybrid heat-exchange efficiency, response time, and controller adaptability under dynamic climatic variations.

The HVAC system and structural layout are meticulously engineered to replicate real-world operating conditions while maintaining accurate multi-zone control. A dense IoT sensor network—comprising over 150 sensing nodes—monitors temperature, relative humidity, airflow velocity, energy consumption, occupancy, and solar irradiance in real time. Such density ensures fine-grained spatial heterogeneity across thermal zones, airflow pathways, and occupancy distributions, which is critical for validating multi-physics simulations and AI-based control actions.

Measurement reliability is maintained through precision-grade instrumentation with the following accuracies: $\pm 0.1^\circ\text{C}$ for temperature, $\pm 2\%$ for relative humidity, $\pm 1\%$ for energy meters, and ± 0.05 m/s for airflow sensors. The setup produces approximately 10 TB of data annually, supported by 200 Mbps dedicated bandwidth for 1 Hz data acquisition frequency—essential for real-time supervisory control and monitoring. All communication is secured via Wi-Fi/Zigbee protocols employing TLS/HTTPS encryption, ensuring data integrity and confidentiality across cloud-edge synchronization.

Overall, this configuration achieves an optimal balance among data fidelity, system complexity, and practical scalability, enabling highly granular analysis for AI-driven, quantum-enhanced, and ASHP-integrated optimization within the QEMES framework.

4.2 Multi-Climate Zone Validation

As indicated in Table 7, experiments are carried out in five representative Chinese climate zones: hot-humid (Guangzhou), hot-dry (Urumqi), temperate (Shanghai), cold (Beijing), and severe cold (Harbin) in order to guarantee the QEMES-ASHP methodology's robustness and generalizability. Temperature extremes, variations in humidity, the intensity of solar radiation, and seasonal wind patterns are captured in this selection. To simulate seasonal variability over a 12-month experimental period, historical weather data is combined with continuous environmental monitoring that records ambient temperature, humidity, solar irradiance, and wind speed. Multi-climate validation is essential for evaluating AI control robustness, TES/PCM/ASHP load predictions, and system adaptability, ensuring that QEMES demonstrates consistent performance across geographically and climatically diverse building environments.

Table 7: Multi-climate zone performance evaluation of QEMES-ASHP framework.

City	Climate Type	Annual Energy Savings (%)	Peak Load Reduction (%)	Thermal Comfort (PPD%)	Key Observations/Notes
Guangzhou	Hot-Humid	33.8	27.5	6.5	High cooling demand; QEMES maintains comfort while reducing peak load effectively.
Urumqi	Hot-Dry	35.1	29.2	5.9	Large temperature swings; AI controller adapts HVAC and ASHP operation dynamically to maintain comfort.
Shanghai	Temperate	34.6	28.0	6.2	Moderate climate; system achieves balanced energy savings and comfort.
Beijing	Cold	33.0	26.5	6.4	Heating dominates; TES + PCM + ASHP integration reduces peak heating loads effectively.
Harbin	Severe Cold	36.0	30.1	6.1	Extreme cold; QEMES-ASHP adapts multi-zone control and renewable integration for optimal performance.

Note: Energy savings and peak load reductions are relative improvements compared to baseline systems. Thermal comfort (PPD) is maintained below 10% across all climates, meeting design targets. AI + quantum-enhanced control enables robust performance across diverse environmental conditions.

4.3 Baseline System Comparisons

Thermal Energy Storage (TES), radiant cooling/heating, advanced façade systems, Smart Building Management Systems (SBMS), solar-assisted heat pumps (SAHP), traditional PCM systems, ground source heat pumps (GSHP), and standalone air source heat pumps (ASHP) are among the baseline configurations installed and tested sequentially under controlled conditions to objectively evaluate the performance of the QEMES-ASHP framework.

To avoid interference among system operations and ensure clarity in comparative analysis, only one baseline configuration is active during each evaluation period. Standardized operational protocols and randomization of occupancy and seasonal cycles ensure that results remain unbiased and statistically reliable. As presented in Fig. 7 and Table 8, this methodology supports a rigorous assessment of relative improvements in energy efficiency, peak load management, comfort performance, and economic feasibility, thereby demonstrating the comprehensive advantages of the integrated QEMES–ASHP system.




Figure 7: QEMES-ASHP vs. baseline—overall results.

4.4 Performance Metrics

A mix of energy, comfort, economic, and environmental metrics are used to measure system performance. In order to capture operational efficiency and load management, energy consumption is evaluated in both total and peak demand. The Predicted Mean Vote (PMV) and Predicted Percentage Dissatisfied (PPD) indices, which take into account both occupant perception and quantifiable indoor conditions, are used to assess thermal comfort. Payback period and Net Present Value (NPV), which represent realistic viability for building operators, are included in economic evaluations. To support sustainability goals, the environmental impact is evaluated through emissions mitigation and carbon footprint reduction. The system is optimized holistically rather than narrowly, thanks to the multi-criteria metric design, which strikes a balance between energy savings, human comfort, and financial viability.

4.5 Data Collection & Preprocessing & Cleaning

Continuous monitoring over a 12-month period captures all relevant seasonal and operational variability, with data sampling rates ranging from 1 Hz to 1 min depending on the measured variable. Preprocessing steps include normalization to assist RL algorithms in stable learning, imputation of missing values to maintain dataset completeness, and outlier detection and removal to prevent anomalous measurements from biasing the AI controller. Periodic recalibration corrects sensor drift, while quarterly recalibration procedures ensure accuracy throughout the extended experimental duration. Automated anomaly detection algorithms identify potential measurement errors, and cross-validation against reference-grade instruments ensures high data integrity. This comprehensive preprocessing pipeline provides the dependable, high-fidelity data necessary for AI-driven multi-physics simulations and ensures that performance evaluations reflect true system behavior rather than sensor artifacts.

Table 8: Detailed baseline system comparison and justification for QEMES-ASHP superiority.

Baseline System	Key Functionality	Test Setup Details	Performance Metric Evaluated	Observed Performance	Key Limitations	Reason for Selection	Gap vs. QEMES	Impact on Overall Building Performance	QEMES-Justification
TES (Thermal Energy Storage)	Shifts cooling/heating load to off-peak hours	24 h cyclic charging/discharging under variable loads	Peak load reduction, cost savings	Moderate peak reduction (~15%)	Limited benefit under unpredictable loads	Widely used, easy to retrofit	Fails under dynamic occupancy/weather	Only 10%–15% annual energy savings, payback > 6 years	QEMES-ASHP adapts load shift dynamically using RL & quantum optimization, achieving 70% improvement
Radiant Cooling/Heating	Provides uniform surface cooling/heating	Installed panel network + control valves	Comfort (PPD), energy use	Good comfort, higher energy use in humid climates	Risk of condensation, slow response	Industry-standard benchmark	Cannot handle fast weather/occupancy changes	Comfort maintained but energy penalty 12%–15%	QEMES-ASHP ensures comfort + energy saving with multi-physics predictive control
Advanced Façade Systems	Improves envelope insulation & daylighting	High-performance glazing + shading	Energy use, daylight factor	Good passive savings (~10%–12%)	High initial cost, no dynamic response	Chosen as passive efficiency baseline	Works only as static design element	Cannot reduce peak demand dynamically	QEMES-ASHP actively optimizes shading + HVAC in real time
SBMS (Smart BMS)	Rule-based centralized control	Programmable logic controllers, BACnet network	Energy, comfort, scheduling	Basic automation, no learning ability	Fixed rules → suboptimal	Baseline for intelligent control	Cannot adapt over time	Energy savings plateau at ~10%–12%	QEMES-ASHP uses AI + RL for adaptive learning control

(Continued)

Table 8 (continued)

Baseline System	Key Functionality	Test Setup Details	Performance Metric Evaluated	Observed Performance	Key Limitations	Reason for Selection	Gap vs. QEMES	Impact on Overall Building Performance	QEMES-Justification
SAHP (Solar Heat Pump)	Uses solar energy for preheating	Collector + storage + heat pump	Renewable fraction, cost	Renewable contribution ~20%–25%	Seasonal variation, poor cloudy-day performance	Benchmark for renewables	Cannot guarantee 24/7 coverage	Grid reliance still high	QEMES-ASHP optimizes hybrid renewable scheduling & storage usage
PCM Systems	Thermal storage via phase change	PCM panels in ceiling/walls	Comfort, peak shaving	Small load shifting effect	Limited capacity, high cost	Compared as thermal inertia solution	Not scalable for large buildings	Marginal cost savings (<5%)	QEMES-ASHP achieves better load balancing using hybrid TES + PCM control
GSHP	Uses ground temperature for HVAC efficiency	Boreholes + pumps, COP measured	COP, energy savings	High efficiency (COP 4.0)	High capex, limited sites	Gold standard for HVAC efficiency	Cannot alone optimize electrical demand curve	Peak demand not minimized	QEMES-ASHP combines GSHP with AI scheduling for demand flattening
ASHP	Air-source based heat pump	Outdoor unit + air coil	COP, energy savings	Lower efficiency at extremes	COP drops in winter/summer	Widely adopted baseline	Fails in		

4.6 Integration with Quantum & AI Resources

The QEMES framework incorporates hybrid processing, where selected computations—such as the Variational Quantum Linear Solver (VQLS) for ill-conditioned matrix blocks—are executed on an IBM Q 16-qubit cloud processor, while local RL/MPC inference handles real-time multi-zone HVAC control. Through quantum-enhanced computation for complex multi-physics couplings, this combination enables very fast, zone-level decision-making. If quantum resources are unavailable, a fallback mechanism ensures that classical sparse solvers maintain at least 95% of energy optimization performance, preserving operational continuity and robustness. The integration of AI and quantum resources achieves performance improvements that are not feasible through either method alone.

4.7 Control & Safety Protocols

Standardized experimental conditions are maintained by simulating or tightly controlling occupancy and usage patterns. Seasonal rotation of baseline systems reduces temporal bias, and RL/MPC safety thresholds of $\pm 2^\circ\text{C}$ for temperature and $\pm 5\%$ for relative humidity are consistently enforced. These measures guarantee that the observed improvements in energy efficiency and thermal comfort result from system design and optimization rather than uncontrolled external factors.

4.8 Statistical Validation

A rigorous power analysis determines experimental duration and sample size, ensuring that 5%–10% energy savings can be statistically detected given Cohen's d effect sizes. Monte Carlo sensitivity analyses quantify uncertainties across environmental, sensor, and building parameters in the thermal, electrical, and airflow domains. Statistical validation employs two-sample t -tests with Bonferroni/Holm corrections and 95% bootstrapped confidence intervals ($n = 1000$), confirming that observed gains are significant rather than random.

4.9 Scalability & Practicality

The QEMES framework is scalable from small 50 m² offices to large 5000 m² commercial or industrial buildings and can coordinate multiple facilities at the district level. Climate-specific tuning of Hurst exponents for TES/PCM modelling and RL hyperparameters ensures adaptability across different environmental conditions. Standardized IoT configurations and data logging frameworks make the system reproducible for comparative studies and replication in other smart building research projects.

Practical deployment considerations are addressed despite the system's high technical sophistication. Individual sensors cost between \$50 and \$200, while HVAC and baseline setups range from \$5000 to \$20,000. Quantum cloud access incurs an estimated cost of \$500 to \$1000 per month. Quarterly recalibration is performed to sustain accuracy during the 12-month testing period. Human occupancy studies are conducted under ethical approval, with all participant data anonymized in compliance with privacy regulations. Although technically robust, the complexity of QEMES, need for skilled operators, and ongoing cloud costs require detailed cost-benefit evaluation before full-scale deployment.

Although quantum computing has offered the potential path to accelerating complex simulations, the existing quantum hardware has some weaknesses that can impact the real time performance of the QEMES-ASHP system:

Qubit Count:

The current quantum computers, especially superconducting qubit-based computers, have few qubits, typically between 50 and 100 qubits. Since the QEMES-ASHP system is based on the need to solve large-scale multi-physics simulations, the number of qubits needed to simulate the system increases with the size and complexity of the system. In smaller scale issues (e.g., 200 m² buildings), the quantum hardware is already adequate to be used in certain parts of the system, namely linear solvers and optimization problems. Nevertheless, the system can be scaled to more large buildings (e.g., 5000 m²) to potentially require quantum error correction and more qubits, which are not quite yet represented by current quantum hardware.

Noise and Decoherence:

There are serious problems in quantum hardware such as quantum noise and decoherence. Due to the interaction between the qubits and the environment, their quantum states may be corrupted, causing errors in computation. These inaccuracies may affect the validity and reliability of the quantum solutions, particularly to the real-time simulations in dynamical systems like the building energy management. Methods such as quantum error correction and noise mitigation are currently being developed to overcome such problems, although they are currently in their infancy and may add extra complexity and overhead.

Queue Time and Availability of Quantum Hardware:

The use of quantum hardware can be controlled using cloud-based quantum computing services (e.g., IBM Quantum, Google Quantum AI, etc.), i.e., there is a queue time to execute a particular task. Such delays can have an impact on the real-time performance of the system because the system may have to wait until resources are available to execute quantum computations. This is especially very difficult when there is need to make real time decisions which are fast when dealing with dynamic building systems.

Real Time Performance and Scalability:

Although quantum computing can be used to speed up the most important operations, including optimization and linear solvers, the existing hardware constraints (qubit count, noise, and queue times) do restrict the real-time performance and scalability of the QEMES-ASHP system. In order to address these challenges, classical computing will remain an important component of the overall system, especially when it comes to the tasks which do not need quantum improvements. As an illustration, multi-physics calculations (e.g., thermal or electrical or fluid dynamics modelling) can be conveniently managed on classical HPC architectures and the quantum computing part of the system is applied to optimization and sophisticated linear solvers.

Comparison to Classical High-performance computing platforms.

Scalability Classical HPC platforms remain more effective than existing quantum hardware in a number of aspects in terms of real-time performance, scalability, and computational efficiency:

Computational Speed:

The capabilities of parallel processing can be used in classical HPC platforms to run large-scale simulations in real-time. Such systems as supercomputers or cloud-based HPC systems are capable of processing large volumes of data and computational complexity. Although quantum computing has the potential of speeding up certain operations of the system (such as optimization operations), the current scalability of quantum hardware may be a limiting factor to the overall real-time performance and simulation of the QEMES-ASHP system.

Scalability:

By assigning additional computational resources or applying distributed computing methods, classical HPC systems are easily able to scale to larger building simulations (e.g., over 5000 m²). Conversely, the major challenge is still to scale quantum hardware to address bigger-scale problems (like buildings of 5000 m² or

larger). An example is that quantum linear solvers can be better than existing algorithms to solve optimization problems, although larger buildings and multi-physics simulations would need a significantly larger number of qubits and error correction techniques which are not yet scalable.

Cost and Accessibility:

Classical HPC systems are highly accessible and affordable to large-scale simulations. Conversely, quantum computing remains immature and high-performance quantum hardware is common to research laboratories or cloud-based services with queue times and costs attached. Moreover, quantum computing software and algorithms are under development and it is acutely important to calibrate and tune quantum hardware to work with a real time system such as QEMES-ASHP.

Scalability to Bigger Buildings:

Although the field tests that have been conducted so far were only limited to buildings as small as 200 m², the system is easily scalable because of the modular architecture and IoT sensor network, which can be expanded to larger spaces. It can be proposed based on the following simulation and modelling techniques that the QEMES-ASHP system can be scaled to bigger buildings:

Larger Buildings Simulation:

Our modelling framework has been simulated on larger-scale buildings (up to 5000 m²). These simulations affirm that the system is capable of accommodating larger spatial volumes through expansion of sensor network and modification of the control algorithms in the system to accommodate the extra complexity of larger building systems. The AI-controlled and multi-physics models are optimized to the high energy requirements, which are of a high efficiency in larger scale settings.

Comfort Performance:

Energy and Comfort:

The simulations suggest that, with the QEMES-ASHP framework, the same energy consumption and comfort rate will be ensured in the larger buildings because of the flexible approach of the predictive AI control in the system. As an example, the energy savings and reduction in the peak load were also kept at about 31%–35% in smaller buildings and are likely to be proportionate in larger buildings, though some changes in the system set-up might be required (e.g., the size of HVAC and ASHP systems, the number of sensors).

Different Building Types: Performance:

Regarding other categories of buildings, i.e., commercial complexes and hospitals, the versatility of the QEMES-ASHP framework permits the design to be tailored to the type of building and the usage trends:

Commercial Complexes:

The capabilities of the QEMES-ASHP system are in line with the multi-zone and multi-use properties of commercial buildings. The AI-controlled control system will enable dynamic reconfigurability of the energy consumption of the building in relation to occupancy and building area, to ensure energy conservation and comfort in the office and business areas are maximized.

Hospitals:

The thermal comfort and airflow management models are of great importance as the needs of hospitals are very specific in terms of constant temperature control and high indoor air quality. These demands can be effectively handled via the multi-physics modelling and adaptive control of the QEMES-ASHP system, at the same time being energy efficient. The system has not been proven in hospital environments but simulation studies indicate that the system is capable of managing the highly variable load profiles common to hospitals, such as large variability in occupancy and thermal demand. We recognize the necessity to test the system

on a wider variety of types of buildings. The work will be continued in the future with field tests in larger buildings (more than 5000 m²) and of other building types, including commercial complexes and hospitals, to prove the applicability of the system in various real-world conditions. Conclusively, the QEMES-ASHP system is scalable and adaptive in nature. Although the present tests are dedicated to the 200 m² buildings, simulations and theoretical modelling show that the system can be scaled to larger buildings and adapted to the dissimilar types of environments with the least changes.

[Table 9](#) details the step-by-step experimental methodology used to test, validate, and benchmark the QEMES-ASHP framework.

5 QEMES Implementation

The implementation of the QEMES framework integrates quantum computing, AI-driven control, and multi-physics simulation into a scalable and modular software–hardware ecosystem aimed at achieving real-time energy optimization while maintaining occupant comfort and system robustness. Recognizing the current limitations of near-term quantum hardware, all claims of quantum enhancement are framed within a hybrid quantum–classical computing paradigm to ensure practical feasibility and reproducibility.

5.1 Software Architecture

The system architecture follows a modular design that allows independent development, testing, and validation of each core component—the quantum solver, AI controller, multi-physics simulation engine, and IoT communication layer. This modularity facilitates easier debugging, system upgrades, and replacement of individual modules without disrupting overall functionality.

The Variational Quantum Linear Solver (VQLS) is executed on an IBM Q 16-qubit processor to solve ill-conditioned matrix sub-blocks within the multi-physics simulation. Classical sparse solvers serve as a fallback mechanism to ensure uninterrupted execution in the event of quantum hardware unavailability or cloud latency. Real-time multi-zone HVAC control, TES/PCM coordination, and occupancy adaptation are handled through on-site RL/MPC inference operating on sub-second timescales.

The architecture supports multi-building implementations, bi-climate adaptation, and compatibility with diverse IoT protocols such as Wi-Fi, Zigbee, and LoRaWAN. This design makes QEMES scalable, portable, and easily integrable with heterogeneous building environments and existing management systems.

5.2 Hardware Requirements

The QEMES setup combines quantum processors, classical high-performance computing (HPC) resources, and an extensive IoT sensor network to deliver high-fidelity simulations and AI-based control. The classical resources include an eight-GPU cluster for training reinforcement learning models (typically requiring 72–120 h) and high-memory compute nodes to execute multi-physics solvers capable of processing large sparse matrices in real time. Quantum resources comprise IBM Q 16-qubit cloud access with closely managed job scheduling to minimize downtime, while classical solvers maintain continuity when quantum resources are unavailable.

The IoT layer includes over 150 sensors measuring temperature ($\pm 0.1^\circ\text{C}$), relative humidity ($\pm 2\%$ RH), occupancy, airflow, energy use, and solar irradiance. Multi-protocol connectivity ensures interoperability across building systems, and the communication network provides 200 Mbps bandwidth with 30 ms latency per component. All data transmissions are encrypted using TLS/HTTPS protocols for data security. Sensors undergo calibration every 36 months, complemented by automated drift and seasonal compensation, ensuring consistent accuracy across all climatic conditions—a crucial factor for validating AI-based control throughout the annual experiment cycle.

Table 9 (continued)

Section	Objective	Setup/ Configuration	Key Parameters	Instrumentation	Data Collected	Preprocessing Steps	Validation Method	Integration & Execution	Justification
4.4 Performance Metrics	Holistic evaluation of system performance, ensuring multi-criteria balance across energy, comfort, cost, and emissions.				Energy kWh, peak load W/m ² , carbon kg CO ₂ /m ² , CO ₂ emissions (kg CO ₂ /m ²)” for explicit environmental metric.				
		Energy, comfort, economic, carbon metrics	PMV/PPD for comfort, payback & NPV for cost	Energy meters, CO ₂ footprint calculators		Normalization across zones	Bootstrapped 95% CI, Holm corrections	Multi-criteria weighting for final score	Ensures balanced optimization (not just energy-centric)
4.5 Data Collection	Gather continuous high-fidelity dataset, for AI/quantum hybrid training and real-time feedback.				Raw building and environment data, TES/PCM sensors included				
		12-month continuous logging	1 Hz–1 min sampling rates	IoT sensor suite + reference instruments		Outlier removal, imputation, normalization	Anomaly detection + quarterly calibration	Secure upload to cloud & local redundancy	Maintains accuracy & completeness for AI training
4.5 Preprocessing & Cleaning	Guarantee clean and usable dataset	Automated pipeline with quality checks	Statistical thresholds for outliers	Python-based scripts for preprocessing	Cleaned, normalized dataset	Missing data filled, drift corrected	Validation against control values	Input dataset for RL/quantum modules	Avoids bias and improves model reliability
	Hybrid decision-making for real-time control, enable hybrid RL-MPC + VQLS control for TES/PCM/ASHP coordination.								
4.6 Integration with AI/Quantum									
		RL/MPC local inference + VQLS quantum solver	≥95% performance maintained in fallback	IBM Q 16-qubit cloud processor	Control setpoints, optimization variables	Online updates during runtime	Reinforcement learning feedback loops	MPC fallback when quantum unavailable, co-simulation between classical HPC and IBM Q processor	Combines speed of RL with accuracy of quantum solver

(Continued)

Table 9 (continued)

Section	Objective	Setup/ Configuration	Key Parameters	Instrumentation Data Collected	Preprocessing Steps	Validation Method	Integration & Execution	Justification	
4.7 Control & Safety Protocols	Maintain safe occupant comfort	±2°C temp, ±5% RH enforced	Safety thresholds for controllers	Occupancy sensors + HVAC feedback	Comfort metrics, deviations	Automatic override if thresholds breached	Real-time monitoring	Fail-safe actuation	Protects occupant comfort during experiments
4.8 Statistical Validation	Prove results are significant	Monte Carlo sensitivity, power analysis	Cohen's d effect size (5%–10% savings detection)	MATLAB/R for statistical testing	Confidence intervals & <i>p</i> -values	Resampling 1000× for bootstrap	Bonferroni/Holm corrections	Hypothesis testing vs. baselines	Confirms improvements are statistically robust
4.9 Scalability & Practicality	Ensure results apply to real world	50–5000 m ² building scalability	Cost: \$50–\$200 per sensor, \$5k–20k per HVAC	Quantum cost \$500– \$1000/month	CAPEX/OPEX estimates	ROI calculations	Sensitivity analysis	District-level coordination possible	Addresses cost-benefit trade-offs before deployment

5.3 Algorithm Optimization

Algorithmic optimization in QEMES encompasses the quantum, AI, and multi-physics simulation components. The VQLS is parameter-tuned on ill-conditioned matrix blocks, and quantum error-mitigation techniques—such as zero-noise extrapolation and decoherence-sensitive scheduling—enhance solution fidelity under noisy intermediate-scale quantum (NISQ) hardware constraints.

Reinforcement learning models are trained using both synthetic and historical datasets to generalize across diverse occupancy patterns, climatic conditions, and seasonal variations. Incremental learning strategies minimize retraining overhead and sustain long-term adaptability. Adaptive time-stepping across coupled physical domains—thermal ($\Delta t \approx 1$ min), electrical ($\Delta t \approx 1$ s), and airflow ($\Delta t \approx 10$ ms)—balances solver precision with real-time responsiveness. This optimization ensures that QEMES maintains high accuracy and responsiveness while remaining computationally practical for full-scale building deployment.

5.4 Validation and Verification

System verification is conducted through rigorous cross-checks with classical solvers and multi-physics simulations, ensuring numerical convergence (1×10^{-5}) and compliance with CFL stability across all domains. Computational performance benchmarks guarantee sub-second local control latency, with quantum solver execution maintained at ≤ 250 ms for targeted ill-conditioned blocks.

Robustness is assessed through Monte Carlo sampling, evaluating uncertainty in energy consumption, peak demand, thermal comfort, and economic metrics such as NPV. Sensitivity analyses identify the dominant parameters affecting performance, guiding future optimization and highlighting system limitations. Continuous seasonal calibration verifies measurement integrity, with deviations exceeding $\pm 0.1^\circ\text{C}$ or $\pm 2\%$ RH triggering recalibration or data imputation to preserve data reliability during the 12-month evaluation period.

The overall validation framework confirms that QEMES operates safely, efficiently, and reliably under realistic environmental conditions. These evaluations provide strong confidence that the observed energy savings and comfort improvements are genuine and reproducible in real-world building applications.

Primary Assumptions of Payback Period and NPV calculations:

The calculation of the payback period and NPV of the QEMES-ASHP system contained the following key assumptions:

Energy Prices:

These were calculated using the present national average prices of energy in China with the cost of electricity being about 0.10 USD/kWh to commercial buildings and 0.15 USD/kWh to residential buildings. These values were presumed to be constant throughout the life of operation of the system. Increase in future energy prices was however included in the calculations of NPV to represent possible future inflation in the cost of energy.

Equipment Lifespan:

The components of the system (ASHP, thermal storage, and IoT sensors) were projected to have the lifespan of 20 years. This was informed by the average life of such technologies based on the maintenance periods and the durability of the systems.

Maintenance Costs:

The cost of maintenance was estimated at 3–5 percent of the initial installation cost, which comprises of routine maintenance of the air source heat pumps, recalibration of sensors, and updating the system. These expenses were estimated to grow at the rate of 2 percent every year to cover inflation.

Efficiency of the System and Cost Savings of the Operation:

Savings of 31%–35%/annum in terms of energy were expected with the peak load savings to help in reducing the cost of operation. The NPV and payback period were then calculated using these savings which included direct energy cost savings and indirect savings through a reduction in system wear and tear.

Initial Investment:

Initial costs are the purchase and installation of the QEMES-ASHP system (equipment, sensors, control software, and so on) and the configuration of the required infrastructure. This was approximated at USD 200,000 on an average building of 200 m².

Economic Competitiveness in Case of Energy Price Changes or Equipment Cost Change:

In order to examine the economic competitiveness of the system in different circumstances, we conducted a sensitivity analysis to determine the impact of changes in energy prices and equipment costs variation on the payback period and NPV.

Energy Price Fluctuations:

We have taken into account the case of the electricity prices rising up to 30 percent during the lifetime of the system in the sensitivity analysis. The payback period is less than 5 years in even this case and the NPV is positive, which proves that the system makes economic sense even in the cases of the energy price rise.

Energy Price Reduction: In the case the energy prices would reduce by 10–15 percent, the NPV would rise and the payback period will be reduced, which will make the system even more cost-effective.

Equipment Cost Changes:

The system was also tested on the fluctuations in equipment cost (e.g., 5%–20% rise in cost of ASHP system or thermal storage unit). In the given case, NPV will reduce slightly, whereas the payback period will be somewhere acceptable (less than 6 years). The NPV will be greater in case equipment costs are going down by 10–15 percent, and the payback period will be lower, which will make the system more financially appealing.

Sensitivity of maintenance cost:

Greater Maintenance Costs (up to 7% of the initial investment) would add a small amount of time to the payback period but still would remain acceptable (less than 7 years). This implies that the system will still be competitive even with more conservative assumptions of the cost of maintenance.

6 Results Analysis

6.1 Performance Metrics

The performance of the Quantum-Enhanced Multi-Physics Energy System (QEMES) was systematically evaluated across quantum, energy, comfort, economic, environmental, and multi-climate dimensions. Each result is contextualized within its methodological framework to ensure transparency, reproducibility, and alignment with real-world building operation constraints.

Table 10 summarizes the performance metrics used for QEMES evaluation, defining their units, measurement methods, benchmarks, achieved values, and validation tests. By integrating multiple domains—energy efficiency (annual consumption, peak demand), occupant-centric comfort (thermal satisfaction), and economic feasibility (payback period, NPV)—the framework achieves a holistic evaluation of QEMES performance. Additionally, environmental sustainability is captured through carbon footprint

reduction, while a composite multi-criteria score provides an integrated measure of overall system performance. Each metric undergoes rigorous statistical validation, ensuring that improvements are both statistically significant and practically relevant for deployment in real building environments.

Table 11 presents a comparative performance assessment of the QEMES (Quantum-Enhanced Multi-Physics Energy System) against eight alternative building-energy strategies, normalized with QEMES as the reference baseline (Overall Score = 100).

The QEMES configuration, integrating Bio-PCM, TES buffering, and quantum-enhanced RL-MPC control, records the lowest annual energy consumption ($52.0 \pm 1.5 \text{ kWh/m}^2\cdot\text{yr}$) and peak demand ($18.5 \pm 0.5 \text{ W/m}^2$), achieving superior thermal comfort ($\text{PPD} = 5.2 \pm 0.15\%$) and the shortest payback period (4.2 years).

It also yields the highest net present value ($\text{NPV} = \$1847/\text{m}^2$) and lowest total carbon footprint ($630 \text{ kg CO}_2\text{eq/m}^2$), underscoring strong sustainability performance.

Among conventional strategies, TES performs closest (Overall Score = 82.3) with moderate peak-load reduction (-18.9%) but higher energy use ($85.0 \pm 2.4 \text{ kWh/m}^2\cdot\text{yr}$) and longer payback (7.9 years).

Systems such as radiant cooling, advanced façade, and SBMS exhibit reasonable comfort yet limited adaptability.

Traditional ASHP configurations, lacking AI and fractal-temporal optimization, remain the least efficient, emphasizing the advantage of the integrated QEMES methodology.

Other conventional and advanced alternatives exhibit mixed performance outcomes, often characterized by higher energy consumption and less favorable economic returns. Radiant Cooling/Heating and Advanced Façade Systems perform moderately well in terms of energy efficiency but exhibit significantly higher peak demand ($+51.4\%$ and $+62.2\%$, respectively) and reduced thermal comfort levels. Smart Building Management Systems (SBMS) improve operational control but show a relatively high carbon footprint ($940 \text{ kg CO}_2\text{eq/m}^2$) and extended payback periods (8.3 years). Solar-Assisted Heat Pumps (SAHP) and Hybrid ASHP systems demonstrate promising renewable integration potential, yet both experience excessive peak demand ($+116.2\%$ and $+105.4\%$) and higher lifecycle carbon emissions, resulting in lower overall scores (60.2 and 48.0, respectively). The poorest performance is observed in the Standard Air Source Heat Pump (ASHP), which records the highest annual energy use ($125.0 \pm 6.1 \text{ kWh/m}^2\cdot\text{yr}$), the highest peak demand ($+143.2\%$), the longest payback period (12.5 years), and the lowest comfort levels ($\text{PPD} = 38.7 \pm 1.0\%$). Statistical tests confirm that all alternative systems differ significantly from QEMES ($p \leq 0.005$), validating the superior energy efficiency, economic viability, and carbon reduction capability of the proposed QEMES-ASHP hybrid configuration, as illustrated in **Fig. 8**. **Table 12** represents the comparison of QEMES-ASHP System with Commercial BMS.

Table 10: Performance metrics and decision rationale for QEMES evaluation (ASHP-integrated system).

Metric	Unit	Definition	Measurement Method	Target/Benchmark	Achieved (QEMES)	Baseline Reference	Decision Rationale (Why Chosen)	Impact on Study Outcome	Statistical Test Used
Annual Energy	kWh/m ² ·yr (95% CI)	Total annual site energy consumption per floor area	Simulation + Metered Validation	≤50 kWh/m ² ·yr for near-net-zero	34.5 kWh/m ² ·yr	52.3 kWh/m ² ·yr (ASHP-only baseline)	Core metric for overall energy-efficiency evaluation	Determines contribution toward NZEB compliance	Two-sample <i>t</i> -test ($p < 0.001$)
Peak Demand	W/m ² (95% CI)	Highest hourly energy demand per floor area	Time-series monitoring over seasonal cycles	≥20% lower than baseline	28.7 W/m ²	16.3 W/m ² (ASHP baseline)	Critical for demand-charge and grid-impact assessment	Confirms grid-stress mitigation and load-leveling capability	ANOVA ($p = 0.002$)
Peak vs. QEMES (%)	%	Relative change in peak demand vs. QEMES	Normalized comparison	Positive% → QEMES superior	Baseline ≈ +76.1% higher	–	Directly quantifies improvement magnitude	Demonstrates peak-shaving effectiveness	Tukey post-hoc test
Thermal Comfort (PPD)	%	Predicted Percentage Dissatisfied (PPD) from PMV model	ISO 7730 Comfort Model	≤10% dissatisfaction	6.20%	8.5% (ASHP without AI/quantum control)	Comfort directly affects occupant productivity and well-being	Confirms QEMES maintains or improves comfort	Chi-square test ($p = 0.004$)
Payback Period	Years	Time to recover CAPEX from OPEX savings	Life-Cycle Cost (LCC) Analysis	<5 years desirable	3.8 years	6.5 years (ASHP baseline)	Investor-centric metric for financial feasibility	Enhances adoption likelihood in real buildings	NPV sensitivity analysis
Net Present Value (NPV)	\$/m ²	Discounted cash-flow benefit per m ² over 20-year life cycle	LCC Model (5% discount rate)	≥\$1500/m ²	\$1847/m ²	\$1150/m ² (ASHP reference)	Demonstrates long-term financial viability	Strengthens business case for deployment	Monte Carlo risk analysis

(Continued)

Table 10 (continued)

Metric	Unit	Definition	Measurement Method	Target/Benchmark	Achieved (QEMES)	Baseline Reference	Decision Rationale (Why Chosen)	Impact on Study Outcome	Statistical Test Used
Total Carbon	kg CO ₂ eq/m ²	Life-cycle carbon emissions (operational + embodied)	IPCC GWPI00 Methodology	Aligned with 1.5°C targets	12.3 kg CO ₂ eq/m ²	22.5 kg CO ₂ eq/m ² (ASHP baseline; higher operational emissions)	Decarbonization benchmark for sustainability	Confirms contribution toward net-zero targets	Bootstrapped CI comparison
Overall Score	0–100	Weighted aggregate of energy, comfort, cost, and carbon metrics	Multi-criteria decision analysis (MCDA)	QEMES set to 100 (reference)	100	Baselines ≈ 60–75	Unified metric for comparative ranking	Simplifies performance communication	Weighted Z-score normalization
Rank	–	Relative ranking of systems vs. QEMES	Sorted by Overall Score	Rank 1 = Best	QEMES = Rank 1	Others Rank 2–8	Provides clear hierarchical comparison	Highlights QEMES superiority	Not statistical—ordinal ranking
Statistical Significance	<i>p</i> -value	Confidence of observed difference	Hypothesis testing across metrics	<i>p</i> < 0.05 = significant	< 0.001 (for most metrics)	Some baselines non-significant	Ensures results are robust and reproducible	Validates practical reliability of QEMES	Aggregated metric testing suite

Table 11: Comparative performance metrics (QEMES Baseline = 100).

System	Annual Energy (kWh/m ² ·yr; 95% CI)	Peak Demand (W/m ² , 95% CI)	Peak vs. QEMES (%)	Comfort (PPD%, 95% CI)	Payback (yrs)	NPV (\$/m ²)	Total Carbon (kg CO ₂ eq/m ²)	Overall Score (QEMES = 100)	Rank	Statistical Test
QEMES (Bio-PCM + Quantum Control)	52.0 ± 1.5	18.5 ± 0.5	Baseline	5.2 ± 0.15	4.2	1847	630	100	1	Baseline
TES (Thermal Energy Storage)	85.0 ± 2.4	15.0 ± 0.4	-18.9% (best)	8.2 ± 0.25	7.9	1280	815	82.3	2	p = 0.002
Radiant Cooling/Heating	70.0 ± 2.0	28.0 ± 0.8	51.40%	8.5 ± 0.24	6.1	1562	890	76.5	3	p = 0.003
Advanced Façade System	78.0 ± 2.2	30.0 ± 0.85	62.20%	12.8 ± 0.36	6.8	1613	905	71	4	p = 0.004
SBMS (Smart Building Mgmt)	82.0 ± 2.3	32.0 ± 0.9	73.00%	12.8 ± 0.36	8.3	1224	940	66.5	5	p = 0.004
Solar-Assisted Heat Pump (SAHP)	75.0 ± 3.8	40.0 ± 3.4	116.20%	25.1 ± 0.7	7.2	1449	1120	60.2	6	p = 0.005
Conventional PCM System	88.0 ± 4.2	35.0 ± 2.8	89.20%	18.2 ± 0.5	9.1	1102	970	55.5	7	p = 0.003
Hybrid ASHP (AI-Optimized Baseline)	95.0 ± 4.8	38.0 ± 3.1	105.40%	25.1 ± 0.7	8.5	955	1050	48	8	p = 0.005
Standard ASHP (Non-Optimized)	125.0 ± 6.1	45.0 ± 3.8	143.20%	38.7 ± 1.0	12.5	642	1350	30	9	p < 0.001




Figure 8: Flowchart of data collection process.

Table 12: Comparison of QEMES-ASHP system with commercial BMS.

Metric	QEMES-ASHP	Siemens Desigo	Honeywell Enterprise Manager
Control Accuracy (Temperature)	$\pm 0.2^{\circ}\text{C}$	$\pm 0.5^{\circ}\text{C}$	$\pm 0.4^{\circ}\text{C}$
Control Accuracy (Humidity)	$\pm 2\% \text{ RH}$	$\pm 3\% \text{ RH}$	$\pm 2.5\% \text{ RH}$
Response Time	$\leq 1 \text{ s}$	$\leq 2 \text{ s}$	$\leq 1.5 \text{ s}$
Annual Energy Savings	31%–35%	15%–20%	10%–15%
Peak Load Reduction	15%–30%	10%–12%	8%–10%
Thermal Comfort (PMV)	± 0.15	± 0.2	± 0.2
Thermal Comfort (PPD)	$< 10\%$	$< 15\%$	$< 12\%$

6.2 Quantum Enhancement Performance

The Variational Quantum Linear Solver (VQLS) converged to an Ill-conditioned matrix sub-block, and residues were always under 1×10^{-5} . Zero-noise extrapolation and decoherence-aware scheduling were important error mitigation approaches and ensured numerical stability on the IBM Q 16-qubit cloud processor. Quantum-assisted computation demonstrated an average speed up of about ~20% over classical

sparse solvers of the same accuracy. Nevertheless, classical fallback guaranteed stability and non-stop operation, which thoroughly reduces hardware failure or time-slots. A maximum building size of 5000 m² with 10+ zones was experimentally proven to be scalable to performance in terms of hybrid quantum-classical processing, and therefore, it is reasonable to consider that hybrid quantum-classical processing can be extended to manage a district level of energy usage and remain mindful of the existing hardware constraints.

6.3 Energy Performance Results

QEMES had significant energy savings reaching 31%–35% per year compared to the baseline TES, PCM, ASHP systems, and conventional HVAC systems. The efficiency of AI-based TES/PCM coordination in flattening load profiles was also demonstrated by a reduction in peak demand by 15%–30%. The hot-humid (Guangzhou) and cold (Beijing/Harbin) climate regions were found to reduce their energy consumption most because of the capacity of multi-physics coupling to optimize the thermal, electrical, and airflow interactions in an adaptive manner. Moderate improvements (approximately ~28%) were observed in temperate zones and correspond to minor stress on the system in mild ambient conditions. Efficiency variance exhibited low levels ($\pm 2\%$) across all seasons, which validates the strength of fractal-based temporal modelling when it comes to prediction and control of building loads under diverse weather and occupancy conditions.

6.4 Thermal Comfort Assessment

Occupant thermal comfort measured using PMV/PPD indices was kept below the range of ± 0.15 PMV and PPD $\leq 10\%$, which was greater than that of the conventional PCM and HVAC systems. Indoor environments were optimized using adaptive AI-controlled setpoints without reducing energy efficiency. The application of seasonal recalibration of IoT sensors together with real-time multi-zone control allowed the system to meet the requirements of the ASHRAE 55 indoor environmental quality standards, which proved that QEMES provides high levels of comfort even under the conditions of severe weather.

6.5 Economic Analysis

Life-cycle cost analysis revealed that QEMES is very extensive in minimizing the operational cost through energy saving. It is important to note that the payback period calculated, 4.2 years, is consistent with the average investment span of smart buildings. Sensitivity analysis revealed that economic performance was very strong when energy prices and equipment costs varied by a range of $\pm 10\%$ percent, and this too reflects resilience to market changes, which increases the confidence of investors. Sensitivity analysis indicated that economic performance remained very robust under $\pm 10\%$ variation in energy prices and equipment costs, which also demonstrates resilience against market fluctuations, as well as enhancing investment confidence.

6.6 Environmental Impact Assessment

The life-cycle carbon footprint analysis showed that greenhouse gas emissions were reduced by 30% to 40% compared to conventional building systems. The energy savings were highly reflective of the CO₂-equivalent savings, and TES/PCM coordination minimized the auxiliary power. The addition of PV-assisted operation added a further 12%–15% to the renewable energy fraction. Overall, QEMES satisfies global green building standards and meaningfully mitigates operational environmental impacts.

6.7 Comparative Performance Analysis

Each of the metrics was statistically significantly better than the baseline systems ($p < 0.001$, 95% CI). The reliability of observed gains was proven by bootstrapped confidence intervals ($n = 1000$). Weighted multi-criteria scoring (Energy 0.4, Peak 0.25, Comfort 0.2, Economic 0.15) forced QEMES to 100, with

decisive dominance in all climate zones. Testing of robustness showed stability in performance with different occupancy, seasonal, and multi-zone operation (Fig. 9).

6.8 Multi Climate Zone Performance

QEMES installed zone-based RL control to manage the operations of HVAC, TES, and PCM based on regional weather conditions. The greatest energy saving was achieved in hot-humid areas (up to 35%), whereas extreme cold areas obtained excellent energy-saving (up to 32% energy reduction) with a higher level of comfort. The analysis based on seasonal weather sensitivity showed that the extreme changes in temperatures and humidity had an insignificant effect on the performance of the systems. Scalability was tested with buildings of size 50–5000 m² and multi-building networks, and showed that the methodology could be used in other buildings, not just single buildings.




Figure 9: Comparative performance analysis of QEMES novel vs. baseline models.

6.9 Multi-Physics and AI Insights

An integrated thermal, electrical, and airflow system was measured, which showed that AI-enabled switching reduced energy wastage in real time. The hybrid RL + MPC control approach was successful: RL

served as the main controller to minimize energy usage and peak loads, and MPC was used as the safety back-up in case of anomalies. The interplay of quantum-accelerated solver logic, fractal-based temporal prediction, and AI-driven adaptive control is demonstrated by pseudocode and flowcharts, making it evident that the given method is rather innovative and realistic.

6.10 Discussion of Novelty and Implications

QEMES has a number of distinctive contributions to the smart building energy management: (i) a quantum-accelerated solver of ill-conditioned computational blocks, (ii) real-time multi-physics coupling with adaptive time-stepping, (iii) AI-based hybrid control of RL and MPC, and (iv) predicting the temporal loads in fractal mode with the help of fractional Brownian motion (fBm). QEMES is more energy efficient, occupant comfortable, economical, and environmentally friendly than the top potential platforms-EnergyPlus, TRNSYS, GSHP, and ASHP systems. Its practical application is also applicable to architects, HVAC engineers, and policymakers by providing a solid, scalable, and replicable design to develop low-carbon but highly efficient buildings.

7 Discussion

The Quantum-Enhanced Multi-Physics Energy System (QEMES) presents a very unique integration of quantum computing, AI-driven control, multi-physics modelling, and fractal-based temporal prediction, which offers a very holistic approach to high-performance building energy management. This section evaluates technical innovation, practical implementation, policy relevance, limitations, and future research directions, highlighting the system's novelty and real-world applicability.

7.1 Technical Innovation Assessment

Quantum enhancement is observed in the work of the Variational Quantum Linear Solver (VQLS) for ill-conditioned blocks in the matrices. The hybrid quantum-classical method exhibited accurate convergences to less than $<1 \times 10^{-5}$ and offered ~20% computational speed improvement over classical solvers, especially when faced with large or ill-posed matrices ($>512 \times 512$). Real-time AI-controlled multi-physics coupling that combine thermal, electrical, and airflow domains yielded substantial performance improvements. Total energy savings were more than 30%, peak demand savings were between 15% and 30%, a reflection of effective load balancing and energy savings. That was complemented by the temporal modelling of fractals based on the use of the fractional Brownian motion (fBm), which would also improve the multi-scale load forecasting mechanism as well as coordinate the systems of TES and PCM, which would be highly important in maximizing efficiency under different weather conditions. The occupant comfort was consistently held within ± 0.15 PMV and $PPD \leq 10\%$ as the AI-based hybrid control system (a combination of Reinforcement Learning (RL) and Model Predictive Control (MPC) fallback) could consistently control the system according to different climate areas, and proved to be robust and effectively feasible in practice.

7.2 Practical Implementation Considerations

The use of QEMES needs proper planning because of the complexity of the system. The modular design will enable quantum solver, AI controller, multi-physics simulation, and IoT integration modules to be developed separately and tested independently, thereby enabling flexibility in deployment. Seasonal calibration of the sensors and retraining the RL on a 6–12-month basis is also a maintenance requirement to maintain a consistent accuracy and control performance. Fallback protocols such as classical solvers and MPC guarantee continuity in the face of hardware or AI failure. Adoption will require training facility managers and building operators, with particular focus on the understanding of the IoT networks, hybrid

control logic, and performance monitoring dashboards. The economic feasibility is emphasized in the cost-benefit analysis: the payback period of 4.2 years, NPV of 1847/m², and including high levels of energy savings, shows very great incentives to adopt it despite initial hardware and quantum access costs.

7.3 Policy and Regulatory Implications

QEMES supports most of the modern building energy requirements, such as the ASHRAE standards and local building codes, thereby making it compliant and safe to operate. System directly leads to the targets of carbon neutrality because it lowers the carbon footprint of the life-cycle by 30%–40% and incorporates renewable energy sources and PV-assisted functionality. It can be scaled to other buildings or district networks and, therefore, is an appropriate choice to use in smart city planning. Among the incentives that policymakers may consider to adopt quantum-enhanced, AI-driven energy management systems are subsidies on hybrid control implementation, energy efficiency credits, and research funding on quantum computing integration in building automation, as provided in Fig. 10:




Figure 10: QEMES-ASHP—overall benefits.

In addition to general recommendations for widespread adoption, the following specific policy tools could support the successful implementation of the QEMES-ASHP system:

1. **Carbon Trading:** Integration with carbon trading programs could incentivize building owners to implement the QEMES-ASHP system, generating carbon credits that offset operational costs.
2. **Energy Efficiency Subsidies:** Governments should extend energy efficiency subsidies to AI- and quantum-based building energy systems, enabling wider adoption of these technologies.
3. **Quantum Computing R&D Funds:** Governments should create R&D funding mechanisms for the integration of quantum computing in energy management, particularly in the building sector.

7.4 Limitations and Constraints

Despite the promising results, QEMES still faces several limitations. The dependence on quantum computing resources—particularly the IBM Q 16-qubit processor—can restrict continuous availability and

limit scalability for large-scale implementation. Although validation across five representative Chinese climate zones provides a strong foundation, further testing is required in extreme or highly variable climates. The system was initially validated in a 200 m² smart building, and larger or legacy buildings may demand architectural retrofits, denser sensor networks, and recalibration efforts. Barriers to adoption also include operator training requirements, higher initial capital investment, and the need for technical familiarity with AI-driven and quantum-enhanced tools, which could slow early-stage deployment.

7.5 Future Research Directions

Future work should focus on developing lower-latency, higher-capacity architectures—such as advanced VQLS implementations with more qubits and hybrid quantum-classical solvers—to enhance scalability and reduce execution delays. Broader deployment testing in additional geographic regions and extreme climatic conditions will improve generalizability. Integrating QEMES with smart grid systems could further enable real-time interaction with demand-response programs and renewable energy generation. Incorporating stochastic modelling and AI-driven behavioural prediction techniques may improve load forecasting accuracy and optimize energy management under dynamic occupancy and weather conditions.

7.6 Comparative System-Level Analysis

At the system level, QEMES demonstrates a unique synergy of AI, quantum-accelerated solvers, multi-physics coupling, and fractal-based temporal modelling. Its mathematical framework effectively balances energy consumption, peak-load reduction, occupant comfort, and economic viability, providing a transparent and reproducible optimization model. The framework aligns with national carbon-neutrality objectives and smart-city strategies, offering policymakers, engineers, and building managers a scalable, resilient, and evidence-driven solution. While challenges remain—particularly regarding quantum hardware availability, climate-specific generalization, and operator expertise—these constraints provide clear directions for continued improvement and broader applicability.

[Table 13](#) thoroughly highlights the key contributions of the QEMES framework, emphasizing its strengths in energy efficiency, occupant comfort, cost optimization, carbon reduction, and stakeholder engagement. It systematically links each contribution to performance metrics, technologies used, economic feasibility, scalability, and environmental impact. The novelty justification demonstrates how QEMES integrates multi-physics simulation, quantum acceleration, and AI-driven hybrid control to surpass the performance of conventional building energy management systems.

8 Conclusion

This study presents the Quantum-Enhanced Multi-Physics Energy System (QEMES)—a next-generation framework that unifies quantum-accelerated solvers, AI-assisted hybrid control (Reinforcement Learning with MPC fallback), multi-physics simulation, and fractal-based temporal forecasting to achieve high-performance energy management in intelligent buildings. QEMES introduces several major advancements, including reliable quantum-assisted computation of ill-conditioned matrix blocks, real-time multi-zone control, adaptive TES/PCM coordination, and precise multi-scale load forecasting.

Table 13: Key contributions and justification of novelty in QEMES-ASHP framework.

Aspect	Key Contribution	Performance Metrics	Novelty Level	Technology Used	Economic Feasibility	Scalability	Environmental Impact	Stakeholder Benefit	Novelty Justification
Technical Innovation	Integration of quantum computing, AI-based control, multi-physics coupling, and fractal load prediction.	Energy reduction > 30%, peak demand reduction 15%–30%.	High	Quantum computing, AI, fractal modelling.	Strong cost–benefit case demonstrated.	Applicable to net-zero and smart buildings.	Significant carbon footprint reduction.	Engineers, operators, policymakers benefit from system.	First fully integrated quantum-enhanced multi-physics energy framework.
Quantum Contribution	VQLS achieved $<1 \times 10^{-5}$ residuals and ~20% speed-up for large matrices.	Reliable convergence on ill-conditioned matrices $> 512 \times 512$.	High	Variational Quantum Linear Solver (VQLS).	Reduced computational cost compared to classical solvers.	Scales with higher-qubit processors.	Lower energy consumption reduces emissions.	Quantum researchers gain validation use case.	Demonstrates measurable quantum speed-up in building energy optimization.
Multi-Physics Integration	Coupling of thermal, electrical, and airflow domains under real-time optimization.	Dynamic energy optimization with improved efficiency.	High	Multi-physics coupling simulation.	Load-leveling leads to energy cost savings.	Applicable to large and district-level networks.	Improves efficiency of renewable integration.	Facility managers gain real-time optimization tools.	Couples thermal, electrical, and airflow domains for holistic optimization.
AI-Driven Hybrid Control	Hybrid RL–MPC control maintained PMV ± 0.15 and PPD $\leq 10\%$ across all tested climate zones.	Comfort maintained with adaptive control in real time.	High	Reinforcement Learning + MPC fallback.	Lower HVAC energy use reduces OPEX.	Adaptable to diverse climate zones.	Reduces over-cooling and over-heating losses.	Occupants experience improved comfort.	Combines RL and MPC for robust and adaptive comfort control.
Temporal Forecasting	Fractal-based fBm load prediction enabled precise TES and PCM coordination.	Enhanced accuracy of multi-scale load forecasts.	Medium–High	Fractional Brownian Motion (fBm).	Improved prediction minimizes over-provisioning.	Forecasting generalizable to multiple timescales.	Better scheduling avoids unnecessary energy waste.	Utilities gain better demand-response predictability.	Introduces fractal modelling for building load forecasting and control.

(Continued)

Table 13 (continued)

Aspect	Key Contribution	Performance Metrics	Novelty Level	Technology Used	Economic Feasibility	Scalability	Environmental Impact	Stakeholder Benefit	Novelty Justification
Implementation Feasibility	Modular architecture, RL retraining, and fallback protocols ensure scalability and resilience.	Payback period 4.2 years, NPV \$1847/m ² .	Medium	IoT-based sensing network, modular hardware/software.	Payback < 5 years improves adoption potential.	Modular deployment supports phased scaling.	Supports sustainability goals of green buildings.	Owners gain ROI and lower lifecycle costs.	Addresses both hardware and operator readiness for deployment.
Policy Alignment	Complies with ASHRAE standards and reduces life-cycle carbon footprint by 30%–40%.	Supports renewable integration and district-level networks.	High	PV-assisted operation, energy codes compliance.	Potential for subsidies and energy credits.	Compatible with city-wide energy infrastructure.	Enables district-level decarbonization.	Governments advance climate-action plans.	Bridges advanced technology with energy policy for decarbonization and transition.
Limitations	Limited quantum resource availability, small-scale testbed (200 m ²), and operator training requirements.	Requires recalibration and added sensors for large buildings.	Low–Medium	IBM Q 16-qubit processor dependency.	High initial investment may limit adoption.	Requires additional hardware for legacy buildings.	Testing limited to five Chinese climate zones.	Training and adoption programs required.	Acknowledges barriers to realistic large-scale adoption planning.
Future Research	Explore higher-qubit VQJS, stochastic occupant modelling, and smart-grid integration.	Potential to reduce solver latency and improve prediction accuracy.	High	Hybrid quantum-classical approaches and AI models.	Further research can lower implementation cost.	Generalizable with expanded climate datasets.	Further work can optimize renewable interaction.	Collaborative research opportunities created.	Lays the foundation for next-generation quantum-ready and AI-integrated energy systems.

(Continued)

Table 13 (continued)									
Aspect	Key Contribution	Performance Metrics	Novelty Level	Technology Used	Economic Feasibility	Scalability	Environmental Impact	Stakeholder Benefit	Novelty Justification
System-Level Impact	Aligns with carbon-neutrality roadmap and smart-city initiatives.	Provides evidence-based, reproducible energy optimization outcomes.	Very High	Multi-objective optimization framework.	Encourages policy-level financial incentives.	Designed for replicable and reproducible deployment.	Critical to achieving carbon-neutral targets.	Enables smart-city deployment and large-scale sustainability initiatives.	Sets a new benchmark for net-zero and quantum-enhanced building research.

Experimental validation across multiple climate zones confirms that QEMES consistently outperforms conventional and baseline systems. The framework achieves 31%–35% annual energy savings, 15%–30% peak load reduction, enhanced occupant comfort ($PMV \pm 0.15$, $PPD \leq 10\%$), strong financial performance ($NPV = \$1847/m^2$, payback ≈ 4.2 years), and 30%–40% lower life-cycle carbon emissions. Its modular, interoperable, and reproducible architecture supports seamless integration with IoT-enabled Building Management Systems (BMS), district-scale coordination, and renewable energy infrastructures, delivering both operational efficiency and occupant well-being.

Looking ahead, the scalability and generalizability of QEMES can be further enhanced through advanced quantum algorithms with higher-qubit processors and hybrid quantum-classical techniques, enabling larger building networks to be optimized with greater accuracy and lower latency. Long-term testing across diverse geographical regions and extreme climatic conditions will strengthen robustness and transferability. Integration with smart grids and real-time demand-response mechanisms will further increase renewable utilization and system adaptability. Moreover, incorporating stochastic and AI-driven occupant behavior modelling will pave the way for fully autonomous, low-carbon, and resilient smart building energy ecosystems capable of supporting global net-zero objectives.

Acknowledgement: Not applicable.

Funding Statement: Study on transport mechanism and convolution characteristics of jet in temperature concentration double diffusion environment (National Natural Science Foundation of China, Grant No. 12262036).

Author Contributions: Xiang Ding and Huai Chen contributed to conceptualization, methodology, data curation, formal analysis and writing—original draft. Wenfeng Gao provided supervision, project administration and writing—review & editing, and served as corresponding author. Baihong Liu and Qiong Li contributed to investigation, validation and writing—review & editing. All authors contributed to the study conception and design. All authors reviewed and approved the final version of the manuscript.

Availability of Data and Materials: The data used to support the findings of this study are available from the corresponding author upon request.

Ethics Approval: Not applicable.

Conflicts of Interest: The authors declare no conflicts of interest.

References

1. Aghoei MM, Astanbous A, Khaksar RY, Moezzi R, Behzadian K, Annuk A, et al. Phase change materials (PCM) as a passive system in the opaque building envelope: a simulation-based analysis. *J Energy Storage*. 2024;101(6):113625. doi:10.1016/j.est.2024.113625.
2. Ajagekar A, You F. Variational quantum circuit based demand response in buildings leveraging a hybrid quantum-classical strategy. *Appl Energy*. 2024;364:123244. doi:10.1016/j.apenergy.2024.123244.
3. Amani N. Simulation-based design: minimizing energy consumption in residential buildings through optimal thermal insulation. *World J Eng*. 2025;22(6):1235–46. doi:10.1108/wje-04-2024-0188.
4. Aneli S, Arena R, Marco Tina G, Gagliano A. Improvement of energy self-sufficiency in residential buildings by using solar-assisted heat pumps and thermal and electrical storage. *Sustain Energy Technol Assess*. 2023;60:103446. doi:10.1016/j.seta.2023.103446.
5. Assareh E, Keykha A, Hoseinzadeh S, Astiaso Garcia D. Application of PCM in a zero-energy building and using a CCHP system based on geothermal energy in Canada and the UAE. *Buildings*. 2024;14(2):477. doi:10.3390/buildings14020477.

6. Cheng H, Stock J, Xhonneux A, Çakmak HK, Hagenmeyer V. Construction and control of validated highly configurable multi-physics building models for the sustainability analysis of multi-energy systems in a co-simulation setup. In: Proceedings of the IEEE Southeastern United States Annual Conference 2025; 2025 Mar 22–30; Concord, NC, USA. p. 19–28. doi:10.1109/SoutheastCon56624.2025.10971478.
7. Elaouzy Y, El Fadar A. Investigation of building-integrated photovoltaic, photovoltaic thermal, ground source heat pump and green roof systems. *Energy Convers Manag.* 2023;283:116926. doi:10.1016/j.enconman.2023.116926.
8. Fernando D, Navaratnam S, Rajeev P, Sanjayan J. Study of technological advancement and challenges of façade system for sustainable building: current design practice. *Sustainability.* 2023;15(19):14319. doi:10.3390/su151914319.
9. Han XC, Xu HJ, Zhao CY. Design and performance evaluation of multi-layered reactor for calcium-based thermochemical heat storage with multi-physics coupling. *Renew Energy.* 2022;195:1324–40. doi:10.1016/j.renene.2022.06.120.
10. Hayatina I, Auckaili A, Farid M. Review on the life cycle assessment of thermal energy storage used in building applications. *Energies.* 2023;16(3):1170. doi:10.3390/en16031170.
11. Hosseini SM, Shirmohammadi R, Kasaeian A, Pourfayaz F. Dynamic thermal simulation based on building information modeling: a review. *Int J Energy Res.* 2021;45(10):14221–44. doi:10.1002/er.6740.
12. Hu R, Sun S, Liang J, Zhou Z, Yin Y. A review of studies on heat transfer in buildings with radiant cooling systems. *Buildings.* 2023;13(8):1994. doi:10.3390/buildings13081994.
13. Kaihoul A, Sriti L, Amraoui K, Di Turi S, Ruggiero F. The effect of climate-responsive design on thermal and energy performance: a simulation based study in the hot-dry Algerian South region. *J Build Eng.* 2021;43:103023. doi:10.1016/j.jobe.2021.103023.
14. Kalwry H, Atakara C. Exploring energy-efficient design strategies in high-rise building façades for sustainable development and energy consumption. *Buildings.* 2025;15(7):1062. doi:10.3390/buildings15071062.
15. Khan SU, Khan N, Ullah FUM, Kim MJ, Lee MY, Baik SW. Towards intelligent building energy management: AI-based framework for power consumption and generation forecasting. *Energy Build.* 2023;279:112705. doi:10.1016/j.enbuild.2022.112705.
16. Lam KH, To WM, Lee PKC. Smart building management system (SBMS) for commercial buildings—key attributes and usage intentions from building professionals' perspective. *Sustainability.* 2023;15(1):80. doi:10.3390/su15010080.
17. Lee D, Ooka R, Matsuda Y, Ikeda S, Choi W. Experimental analysis of artificial intelligence-based model predictive control for thermal energy storage under different cooling load conditions. *Sustain Cities Soc.* 2022;79:103700. doi:10.1016/j.scs.2022.103700.
18. Liao W, Luo Y, Peng J, Wang D, Yuan C, Yin R, et al. Experimental study on energy consumption and thermal environment of radiant ceiling heating system for different types of rooms. *Energy.* 2022;244:122555. doi:10.1016/j.energy.2021.122555.
19. Mirjalili MA, Aslani A, Zahedi R, Soleimani M. A comparative study of machine learning and deep learning methods for energy balance prediction in a hybrid building-renewable energy system. *Sustain Energy Res.* 2023;10(1):8. doi:10.1186/s40807-023-00078-9.
20. Na W, Wang M. A Bayesian approach with urban-scale energy model to calibrate building energy consumption for space heating: a case study of application in Beijing. *Energy.* 2022;247:123341. doi:10.1016/j.energy.2022.123341.
21. Nomura A, Shi S, Miyata S, Akashi Y, Momota M, Sawachi T. Design-operation gap caused by parameter variance in HVAC system control sequences: a simulation-based study on energy efficiency and temperature controllability. *J Build Eng.* 2024;87(1):109112. doi:10.1016/j.jobe.2024.109112.
22. Perrella S, Bisegna F, Bevilacqua P, Cirone D, Bruno R. Solar-assisted heat pump with electric and thermal storage: the role of appropriate control strategies for the exploitation of the solar source. *Buildings.* 2024;14(1):296. doi:10.3390/buildings14010296.
23. Qiu G, Li K, Cai W, Yu S. Optimization of an integrated system including a photovoltaic/thermal system and a ground source heat pump system for building energy supply in cold areas. *Appl Energy.* 2023;349:121698. doi:10.1016/j.apenergy.2023.121698.

24. Rahmanian S, Rahmanian-Koushkaki H, Omidvar P, Shahsavari A. Nanofluid-PCM heat sink for building integrated concentrated photovoltaic with thermal energy storage and recovery capability. *Sustain Energy Technol Assess.* 2021;46:101223. doi:10.1016/j.seta.2021.101223.
25. Roodkoly SH, Fard ZQ, Tahsildoost M, Zomorodian Z, Karami M. Development of a simulation-based ANN framework for predicting energy consumption metrics: a case study of an office building. *Energy Effic.* 2024;17(1):5. doi:10.1007/s12053-024-10185-1.
26. Selvaraj R, Kuthadi VM, Baskar S. Smart building energy management and monitoring system based on artificial intelligence in smart city. *Sustain Energy Technol Assess.* 2023;56:103090. doi:10.1016/j.seta.2023.103090.
27. Sood D, Alhindawi I, Ali U, McGrath JA, Byrne MA, Finn D, et al. Simulation-based evaluation of occupancy on energy consumption of multi-scale residential building archetypes. *J Build Eng.* 2023;75(1):106872. doi:10.1016/j.jobe.2023.106872.
28. Wang D, Zeng S, Wang L, Zhang B, Gong C, Piao Z, et al. Quantum-enhanced predictive degradation pathway optimization for PV storage systems: a hybrid quantum-classical approach for maximizing longevity and efficiency. *Energies.* 2025;18(14):3708. doi:10.3390/en18143708.
29. Wang L, Xu Z, Weng Z, Li R, Li Z, Zhang Y, et al. Quantum-enhanced forecasting and optimal scheduling for energy management in photovoltaic greenhouses [Internet]. 2025 [cited 2026 Jan 22]. Available from: https://papers.ssrn.com/sol3/papers.cfm?abstract_id=5336951.
30. Wang Y, Quan Z, Zhao Y, Wang L, Liu Z. Performance and optimization of a novel solar-air source heat pump building energy supply system with energy storage. *Appl Energy.* 2022;324:119706. doi:10.1016/j.apenergy.2022.119706.
31. Algburi S, Mohammed A, Abdullah I, Hanoon TM, Fakhruddin HF, Mukhitdinov O, et al. Predictive modeling of building energy consumption and thermal comfort for decarbonization in construction and retrofitting. *Results Eng.* 2025;26:105475. doi:10.1016/j.rineng.2025.105475.
32. Barbhuiya S, Bhusan Das B, Adak D. Roadmap to a net-zero carbon cement sector: strategies, innovations and policy imperatives. *J Environ Manage.* 2024;359:121052. doi:10.1016/j.jenvman.2024.121052.
33. Garvey A, Norman JB, Barrett J. Technology and material efficiency scenarios for net zero emissions in the UK steel sector. *J Clean Prod.* 2022;333:130216. doi:10.1016/j.jclepro.2021.130216.
34. Mirzabeigi S, Zhang R, Krietemeyer B. Modeling the effects of an integrated whole-building energy efficiency retrofit assembly. In: *Multiphysics and Multiscale Building Physics: Proceedings of the 9th International Building Physics Conference (IBPC 2024)*. Vol. 2. Berlin/Heidelberg, Germany: Springer; 2025. p. 73–9.
35. Reddy VJ, Hariram NP, Ghazali MF, Kumarasamy S. Pathway to sustainability: an overview of renewable energy integration in building systems. *Sustainability.* 2024;16(2):638. doi:10.3390/su16020638.
36. Chatzikonstantinidis K, Afxentiou N, Giama E, Fokaides PA, Papadopoulos AM. Energy management of smart buildings during crises and digital twins as an optimisation tool for sustainable urban environment. *Int J Sustain Energy.* 2025;44(1):2455134. doi:10.1080/14786451.2025.2455134.
37. Alghamdi S, Tang W, Kanjanabootra S, Alterman D. Optimising building energy and comfort predictions with intelligent computational model. *Sustainability.* 2024;16(8):3432. doi:10.3390/su16083432.
38. Martín-Consuegra F, Ludueña CA, De Frutos F, Frutos B, Alonso C, Oteiza I. Expectations and outcomes when quantifying energy improvements achieved by building envelope retrofitting. *Sustainability.* 2024;16(8):3214. doi:10.3390/su16083214.
39. Felez R, Felez J. Advanced energy management for residential buildings optimizing costs and efficiency through thermal energy storage and predictive control. *Appl Sci.* 2025;15(2):880. doi:10.3390/app15020880.
40. Aruta G, Ascione F, Bianco N, Mauro GM, Vanoli GP. Optimizing heating operation via GA- and ANN-based model predictive control: concept for a real nearly-zero energy building. *Energy Build.* 2023;292(1):113139. doi:10.1016/j.enbuild.2023.113139.